

COLORADO DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT

MONTHLY OPERATIONAL REPORT - Data Sheet

SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Required Number of Turbidity Readings Per Day: 1

DAY	TURBIDITY (NTU)								RESIDUAL DISINFECTANT (mg/L)								12. COMMENTS	RECEIVED NOV 07 2012
	☐ Continuous Sampling ☒ Grab Sampling								☐ Continuous Sampling ☒ Grab Sampling									
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12	HIGHEST TURBIDITY READING	TIME TURBIDITY READ	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12	LOWEST RESIDUAL READING			
1							.52	4:00 P								1.0		
2							.32	10:45 A								1.1		
3							.38	11:00 A								1.1		
4							.32	12:30 P								1.1		
5							.36	2:00 P								1.1		
6							.32	3:00 P								1.1		
7							.55	1:20 P								1.0		
8							.31	11:30 A								.9		
9							.21	2:30 P								1.0		
10							.17	3:30 P								.9		
11							.34	4:30 P								.9		
12							.26	4:10 P								.9		
13							.76	10:30 A								.9		
14							.44	12:45 P								.8		
15							.24	4:30 P								.8		
16							.19	11:30 A								1.0		
17							.71	6:45 P								1.0		
18							.21	3:30 P								.9		
19							.40	3:30 P								.8		
20							.32	3:30 P								.9		
21							.39	2:30 P								.7		
22							.33	10:30 A								.8		
23							.32	2:00 P								.9		
24							.27	2:30 P								.7		
25							.73	11:15 A								.8		
26							.79	2:15 P								.8		
27							.72	3:45 P								.9		
28							.32	12:10 P								.8		
29							.41	11:15 A								.9		
30							.21	1:00 P								.7		
31							.26	2:30 P								.8		

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.

Meadow Mountain
Water Supply
PWSID #: 00-0201504

Oct 2012