



Colorado Department
of Public Health
and Environment

Colorado Department of Public Health and Environment
Compliance Assurance & Data Management Unit

REPORTING FORM FOR BACTERIOLOGICAL ANALYSIS

SAMPLER: FILL OUT ONE FORM - FOR EACH INDIVIDUAL SAMPLING POINT

PWSID #: CO0 207504 COUNTY: _____ DATE COLLECTED: 4, 4, 13
SYSTEM/ESTABLISHMENT NAME: Meadow Mountain
SYSTEM MAILING ADDRESS: P.O. Box 354
CONTACT PERSON: Steve Tedford CITY _____ STATE _____ ZIP _____
PHONE: () _____
SAMPLE COLLECTED BY: Steve Tedford TIME COLLECTED: 7:15 am/pm
WATER TYPE: RAW (No chlorine or other treatment) ☐ CHLORINATED ☒ OTHER TREATMENT ☐

SAMPLE POINT (Address)	CHLORINE RESIDUAL in mg/L	SAMPLE TYPE
<u>Bieber</u>	<u>1.1</u>	<input checked="" type="checkbox"/> Routine <input type="checkbox"/> Repeat <input type="checkbox"/> Special Purpose

For Laboratory Use Only Below This Line
LABORATORY SAMPLE # 00130133 CLIENT NAME or ID# Meadow Mountain
LABORATORY NAME: CHD DIAGNOSTIC LAB PHONE # 970 532 2078
DATE RECEIVED IN LABORATORY 4.4.13 DATE ANALYZED 4.5.13
COMMENTS: _____

PARAMETER	RESULT	UNITS	ANALYSIS DATE	LABORATORY METHOD
Coliform, TOTAL (Verified)		#/100 mL		
Coliform, FECAL/e. Coli (Verified)		#/100 mL		
Coliform, TOTAL (Absent/Present)	<u>Absent</u>		<u>4/5/13 2:05 pm</u>	<u>24 Coli test</u>
Coliform, FECAL/e. Coli (Absent/Present)				

LABORATORY: Please call Drinking Water Section with any results other than < 1 or ABSENT.

NT = Not Tested for compound

TNTC = Too Numerous To Count - Please resample

OD = Outdated - Please resample

<1 = Safe valid sample

Present Coliform / e. Coli / Fecal detected

#/100 ml = Number of colonies per 100 ml of sample

CG = Confluent Growth - Please resample

EA = Lab. Accident - Please resample

Absent = Coliform / e. Coli / Fecal not detected

T. Ben YS Pres. Dent 4, 16, 13
Reviewed & Approved by Title Date

LABORATORY ANALYTICAL REPORT

Customer 20011350
Meadow Mountain Water
PO Box 354
Allenspark, CO 80510
PWSID: CO 0207504

Invoice Number: 20130133
Received Date & Time: 4/4/2013 2:00PM
Arrival Temperature: 13.4°C

Sample Identification: Biebel, Finished

Sample Information: Chlorinated; unrec. NTU

Sample Date & Time: 4/4/2013 7:15AM

Sampler: Steve Tedford

Volume Sampled: 100ml

Sample Type: Grab

Processing Date & Time: 4/4/2013 2:05PM

Analytical Method: 9223B, IDEXX Colilert® with QuantiTray® 2000

Start Date & Time: 4/4/2013 2:05PM

Amount Analyzed: 100ml

Stop Date & Time: 4/5/2013 2:05PM

Additional Start Date & Time: N/A

Dilution factor: N/A

Additional Stop Date & Time: N/A

Analytical Results:

Analyte Reporting Limit: 1.0

Coliform bacteria: ABSENT

Chlorine Residual: 1.1

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.


Report Approved By

Title

Date

CH Diagnostic Consulting Service, Inc.
512 5th Street, Berthoud CO 80513
PH: (970) 532 2078 FX: (970) 532 3358