

JANUARY 2013

COLORADO DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT
MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Meadow-Mountain
 US

Required Number of Turbidity Readings Per Day: 1

PWSID #: 00-0207504

DAY	TURBIDITY (NTU)								RESIDUAL DISINFECTANT (mg/L)								12. COMMENTS
	☐ Continuous Sampling ☒ Grab Sampling								☐ Continuous Sampling ☒ Grab Sampling								
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12	HIGHEST TURBIDITY READING	TIME TURBIDITY READ	ENTRY POINT TO DISTRIBUTION						LOWEST RESIDUAL READING		
									12 to 4	4 to 8	8 to 2	12 to 4	4 to 8	8 to 12			
1			.38				.38	12:00A			.9				.9		
2			.42				.42	8:30A			.9				.9		
3				.36			.36	1:20P				.9			.9		
4					.38		.38	4:30P				.9			.9		
5			.42				.42	11:30P			.9				.9		
6				.61			.61	3:30				.8			.8		
7			.21				.21	9:30			.8				.8		
8			.30				.30	11:30			.8				.8		
9			.63				.63	11:30			.8				.8		
10				.48			.48	1:30P				.9			.9		
11					.42		.42	8:45P						.9	.9		
12			.50				.50	10:50A			.9				.9		
13			.48				.48	11:30A			.9				.9		
14			.57				.57	11:30A			.8				.8		
15				.52			.52	3:15P				.9			.9		
16				.44			.48	3:45P				.9			.9		
17					.42		.42	4:15P					.9		.9		
18				.46			.46	3:45P				.9			.9		
19				.42			.42	12:10P				.9			.9		
20				.40			.40	12:15P				.9			.9		
21			.49				.49	11:15P			.9				.9		
22			.42				.42	9:15A			.9				.9		
23				.46			.48	3:15P				.9			.9		
24				.56			.56	12:30P				.9			.9		
25				.42			.42	3:10P				.9			.9		
26				.46			.46	2:15P				.9			.9		
27			.42				.42	11:45P			.9				.9		
28			.64				.64	11:15A			.8				.8		
29					.54		.54	9:15P					.8		.8		
30				.39			.39	12:15P				.9			.9		
31				.42			.42	1:15P				.9			.9		

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.