



Colorado Department
of Public Health
and Environment

Colorado Department of Public Health and Environment
Compliance Assurance & Data Management Unit

REPORTING FORM FOR BACTERIOLOGICAL ANALYSIS

SAMPLER: FILL OUT ONE FORM - FOR EACH INDIVIDUAL SAMPLING POINT

PWSID #: CO 207504 COUNTY: _____ DATE COLLECTED: 2, 11, 14
SYSTEM/ESTABLISHMENT NAME: Meadow Mountain
SYSTEM MAILING ADDRESS: PO. Box 354
CONTACT PERSON: Steve Tedford CITY: _____ STATE: _____ ZIP: _____
PHONE: () _____
SAMPLE COLLECTED BY: Steve Tedford TIME COLLECTED: 700 am/pm
WATER TYPE: RAW (No chlorine or other treatment) ☐ CHLORINATED ☒ OTHER TREATMENT ☐

SAMPLE POINT (Address)	CHLORINE RESIDUAL in mg/L	SAMPLE TYPE
<u>Newton</u>	<u>0.2</u>	☒ Routine ☐ Repeat ☐ Special Purpose

For Laboratory Use Only Below This Line
LABORATORY SAMPLE # 20140032 CLIENT NAME or ID# Meadow Mountain
LABORATORY NAME: CHDIA6 UOSTIC LAB PHONE # 970 532 2078
DATE RECEIVED IN LABORATORY 2, 11, 14 DATE ANALYZED 2, 12, 14
COMMENTS: _____

PARAMETER	RESULT	UNITS	ANALYSIS DATE	LABORATORY METHOD
Coliform, TOTAL (Verified)		#/100 mL		
Coliform, FECAL/e. Coli (Verified)		#/100 mL		
Coliform, TOTAL (Absent/Present)	<u>Absent</u>		<u>2/12/14 1400</u>	<u>24 Coli test</u>
Coliform, FECAL/e. Coli (Absent/Present)				

LABORATORY: Please call Drinking Water Section with any results other than <1 or ABSENT.

NT = Not Tested for compound

TNTC = Too Numerous To Count - Please resample

Q1 = (untitled) - Please resample

<1 = Safe, valid sample

Present Coliform/e. Coli Present detected

#/100 ml = Number of colonies per 100 ml of sample

CG = Confirmed Growth - Please resample

LA = Lab. Accident - Please resample

Absent = Coliform / e. Coli / fecal not detected

Shawn Guld Office Admin 2/14/14
Title Date

LABORATORY ANALYTICAL REPORT

Customer 20011350
Meadow Mountain Water
PO Box 354
Allenspark, CO 80510
PWSID: CO 0207504

Invoice Number: 20140032
Received Date & Time: 2/11/2014 8:30AM
Arrival Temperature: 9.8°C

Sample Identification: Newton

Sample Information: unrec. NTU

Sample Date & Time: 2/11/2014 unrec.

Sampler: Steve Tedford

Volume Sampled: 100ml

Sample Type: Grab

Processing Date & Time: 2/11/2014 2:00PM

Analytical Method: 9223B, IDEXX Colilert® with QuantiTray® 2000

Start Date & Time: 2/11/2014 2:00PM

Amount Analyzed: 100ml

Stop Date & Time: 2/12/2014 2:00PM

Additional Start Date & Time: N/A

Dilution factor: N/A

Additional Stop Date & Time: N/A


Analytical Results:

Analyte Reporting Limit: 1.0


Coliform bacteria: ABSENT

Chlorine Residual: 0.2

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.



Report Approved By



Title

Date