



Colorado Department
of Public Health
and Environment

Colorado Department of Public Health and Environment
Compliance Assurance & Data Management Unit

REPORTING FORM FOR BACTERIOLOGICAL ANALYSIS

SAMPLER: FILL OUT ONE FORM - FOR EACH INDIVIDUAL SAMPLING POINT

PWSID #: CO0 207504 COUNTY: _____ DATE COLLECTED: 3, 6, 14
SYSTEM/ESTABLISHMENT NAME: Meadow Mountain Water
SYSTEM MAILING ADDRESS: P.O. Box 354 Allenspark CO 80510
CONTACT PERSON: Steve Tedford PHONE: () _____
SAMPLE COLLECTED BY: Steve Tedford TIME COLLECTED: 6:50 am
WATER TYPE: RAW (No chlorine or other treatment) ☐ CHLORINATED ☒ OTHER TREATMENT ☐

SAMPLE POINT (Address)	CHLORINE RESIDUAL in mg/L	SAMPLE TYPE
<u>Kesson</u>	<u>0.2</u>	☒ Routine ☐ Repeat ☐ Special Purpose

For Laboratory Use Only Below This Line
LABORATORY SAMPLE # 20140052 CLIENT NAME or ID# Meadow Mountain Water
LABORATORY NAME: CHD DIAGNOSTIC LAB PHONE # 970.532.2078
DATE RECEIVED IN LABORATORY 3, 6, 14 DATE ANALYZED 3, 7, 14
COMMENTS: _____

PARAMETER	RESULT	UNITS	ANALYSIS DATE	LABORATORY METHOD
Coliform, TOTAL (Verified)		#/100 mL		
Coliform, FECAL/e. Coli (Verified)		#/100 mL		
Coliform, TOTAL (Absent/Present)	<u>Absent</u>		<u>3/7/14 11:40am</u>	<u>24 Coli-Test</u>
Coliform, FECAL/e. Coli (Absent/Present)				

LABORATORY: Please call Drinking Water Section with any results other than <1 or ABSENT.

NT = Not Tested for compound

TNTC = Too Numerous To Count - Please resample

OD = Outdated - Please resample

<1 = Safe valid sample

Present Coliform / e. Coli (Seen) detected

#/100 ml = Number of colonies per 100 ml of sample

CG = Confluent Growth - Please resample

LA = Lab. Accident - Please resample

Absent = Coliform / e. Coli / fecal not detected

Reviewed & Approved by [Signature]

Title Official Admin

Date 3, 19, 14

LABORATORY ANALYTICAL REPORT

Customer 20011350
Meadow Mountain Water
PO Box 354
Allenspark, CO 80510
PWSID: CO 0207504

Invoice Number: 20140052
Received Date & Time: 3/6/2014 9:30AM
Arrival Temperature: 20.2°C

Sample Identification: Kesson

Sample Information: unrec. NTU

Sample Date & Time: 3/6/2014 6:50AM

Sampler: Steve Tedford

Volume Sampled: 100ml

Sample Type: Grab

Processing Date & Time: 3/6/2014 11:40AM

Analytical Method: 9223B, IDEXX Colilert® with QuantiTray® 2000

Start Date & Time: 3/6/2014 11:40AM

Amount Analyzed: 100ml

Stop Date & Time: 3/7/2014 11:40AM

Additional Start Date & Time: N/A

Dilution factor: N/A

Additional Stop Date & Time: N/A


Analytical Results:

Analyte Reporting Limit: 1.0

Coliform bacteria: ABSENT

Chlorine Residual: 0.2

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.


Report Approved By

Title

Date