



Colorado Department
of Public Health
and Environment

Colorado Department of Public Health and Environment
Compliance Assurance & Data Management Unit

REPORTING FORM FOR BACTERIOLOGICAL ANALYSIS

SAMPLER: FILL OUT ONE FORM - FOR EACH INDIVIDUAL SAMPLING POINT

PWSID #: CO 207504 COUNTY: _____ DATE COLLECTED: 5.5.14
SYSTEM/ESTABLISHMENT NAME: Meadow Mountain
SYSTEM MAILING ADDRESS: P.O. Box 354 Allenspark, CO 80510
CONTACT PERSON: Steve Tedford CITY _____ STATE _____ ZIP _____
PHONE: () _____
SAMPLE COLLECTED BY: Steve Tedford TIME COLLECTED: 615 (am/pm)
WATER TYPE: RAW (No chlorine or other treatment) ☐ CHLORINATED ☐ OTHER TREATMENT ☐

SAMPLE POINT (Address)	CHLORINE RESIDUAL in mg/L	SAMPLE TYPE
<u>Rust</u>	<u>0.1</u>	☒ Routine ☐ Repeat ☐ Special Purpose

For Laboratory Use Only Below This Line
LABORATORY SAMPLE # 20140132 CLIENT NAME or ID# Meadow Mountain
LABORATORY NAME: CHD DIAGNOSTIC LAB PHONE # 970 532 2078
DATE RECEIVED IN LABORATORY 1/1 DATE ANALYZED 5.6.14
COMMENTS: _____

PARAMETER	RESULT	UNITS	ANALYSIS DATE	LABORATORY METHOD
Coliform, TOTAL (Verified)		#/100 mL		
Coliform, FECAL/e. Coli (Verified)	<u>Absent</u>	#/100 mL	<u>5/6/14 1154</u>	<u>24 Colilert</u>
Coliform, TOTAL (Absent/Present)				
Coliform, FECAL/e. Coli (Absent/Present)				

LABORATORY: Please call Drinking Water Section with any results other than <1 or ABSENT.

NT = Not Tested for compound

TWTC = Too Numerous To Count - Please resample

OI = Outlined - Please resample

<1 = Safe water sample

Present Coliform / e. Coli / fecal detected

#/100 ml = Number of colonies per 100 ml of sample

CG = Confluent Growth - Please resample

LA = Lab. Accident - Please resample

Absent = Coliform / e. Coli / fecal not detected

Shawn O'Leary OFFICE ADMIN 5.28.14
Reviewed & Approved by _____ Title _____ Date _____

LABORATORY ANALYTICAL REPORT

Customer 20011350
Meadow Mountain Water
PO Box 354
Allenspark, CO 80510
PWSID: CO 0207504

Invoice Number: 20140132
Received Date & Time: 5/5/2014 9:00
Arrival Temperature: 9.8°C

Sample Identification: RUSH

Sample Information: unrec. NTU

Sample Date & Time: 5/5/2014 6:15AM

Sampler: Steve Tedford

Volume Sampled: 100ml

Sample Type: Grab

Processing Date & Time: 5/5/2014 11:54AM

Analytical Method: 9223B, IDEXX Colilert® with QuantiTray® 2000

Start Date & Time: 5/5/2014 11:54AM

Amount Analyzed: 100ml

Stop Date & Time: 5/6/2014 11:54AM

Additional Start Date & Time: N/A

Dilution factor: N/A

Additional Stop Date & Time: N/A

Analytical Results:

Analyte Reporting Limit: 1.0

Coliform bacteria: ABSENT

Chlorine Residual: 0.1

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.

Report Approved By

Title

Date