



Colorado Department
of Public Health
and Environment

Colorado Department of Public Health and Environment
Compliance Assurance & Data Management Unit

REPORTING FORM FOR BACTERIOLOGICAL ANALYSIS

SAMPLER: FILL OUT ONE FORM - FOR EACH INDIVIDUAL SAMPLING POINT

PWSID #: COO 207504 COUNTY: _____ DATE COLLECTED: 6.4.14
SYSTEM/ESTABLISHMENT NAME: Meadow Mountain
SYSTEM MAILING ADDRESS: PO BOX 354 Allenspark CO 80510
CONTACT PERSON: Steve Tedford CITY _____ STATE _____ ZIP _____
PHONE: () _____
SAMPLE COLLECTED BY: Steve Tedford TIME COLLECTED: 145 am/pm
WATER TYPE: RAW (No chlorine or other treatment) ☐ CHLORINATED ☐ OTHER TREATMENT ☐

SAMPLE POINT (Address)	CHLORINE RESIDUAL in mg/L	SAMPLE TYPE
<u>RUCH</u>	<u>0.4</u>	☒ Routine ☐ Repeat ☐ Special Purpose

For Laboratory Use Only Below This Line
LABORATORY SAMPLE # 20140203 CLIENT NAME or ID# Meadow Mountain
LABORATORY NAME: CHDIAGNOSTIC LAB PHONE # (970) 532-2078
DATE RECEIVED IN LABORATORY 6.3.14 DATE ANALYZED 6.4.14
COMMENTS: _____

PARAMETER	RESULT	UNITS	ANALYSIS DATE	LABORATORY METHOD
Coliform, TOTAL (Verified)		#/100 mL		
Coliform, FECAL/c. Coli (Verified)		#/100 mL		
Coliform, TOTAL (Absent/Present)	<u>Absent</u>		<u>6/4/14</u>	<u>24 Coli/rt</u>
Coliform, FECAL/c. Coli (Absent/Present)				

LABORATORY: Please call Drinking Water Section with any results other than <1 or ABSENT.

NT = Not Tested for component

TNTC = Too Numerous To Count - Please resample

Q1 = (untreated) - Please resample

<1 = Safe: valid sample

Present Coliform / c. Coli / fecal detected

#/100 ml = number of colonies per 100 ml of sample

CG = Confluent Growth - Please resample

LA = Lab. Accident - Please resample

Absent = Coliform / c. Coli / fecal not detected

Reviewed & Approved by [Signature] Title Office Admin Date 6.30.14

LABORATORY ANALYTICAL REPORT

Customer 20011350
Meadow Mountain Water
PO Box 354
Allenspark, CO 80510
PWSID: CO 0207504

Invoice Number: 20140205
Received Date & Time: 6/3/2014 3:25PM
Arrival Temperature: 22°C

Sample Identification: Unrec.

Sample Information:

Sample Date & Time: 6/3/2014 1:45PM

Sampler: Steve Tedford

Volume Sampled: 100ml

Sample Type: Grab

Processing Date & Time: 6/3/2014 3:40PM

Analytical Method: 9223B, IDEXX Colilert® with QuantiTray® 2000

Start Date & Time: 6/3/2014 3:40PM

Amount Analyzed: 100ml

Stop Date & Time: 6/4/2014 3:40PM

Additional Start Date & Time: N/A

Dilution factor: N/A

Additional Stop Date & Time: N/A


Analytical Results:

Analyte Reporting Limit: 1.0

Coliform bacteria: ABSENT

Chlorine Residual: 0.4

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.



Report Approved By

Title **Date**

CH Diagnostic Consulting Service, Inc.
512 5th Street, Berthoud CO 80513
PH: (970) 532 2078 FX: (970) 532 3358