



Colorado Department
of Public Health
and Environment

Colorado Department of Public Health and Environment
Compliance Assurance & Data Management Unit

REPORTING FORM FOR BACTERIOLOGICAL ANALYSIS

SAMPLER: FILL OUT ONE FORM - FOR EACH INDIVIDUAL SAMPLING POINT

PWSID #: CO 0207504 COUNTY: _____ DATE COLLECTED: 11/5/2014

SYSTEM/ESTABLISHMENT NAME: MEADOW MOUNTAIN WATER

SYSTEM MAILING ADDRESS: PO BOX 354 ALLENSPARK, CO 80510
Street address/PO Box CITY STATE ZIP

CONTACT PERSON: STEVE TEDFORD PHONE: _____

SAMPLE COLLECTED BY: STEVE TEDFORD TIME COLLECTED: 7:30AM

WATER TYPE: RAW (No chlorine or other treatment) ☐ CHLORINATED ☒ OTHER TREATMENT ☐

SAMPLE POINT (Address)	CHLORINE RESIDUAL in mg/L	SAMPLE TYPE
PLANT	1.3	<input checked="" type="checkbox"/> Routine <input type="checkbox"/> Repeat <input type="checkbox"/> Special Purpose

For Laboratory Use Only Below This Line

LABORATORY SAMPLE # 20140633 CLIENT NAME or ID# DEERWOOD SERVICE CO.

LABORATORY NAME: CH Diagnostic & Consulting Service, Inc. LAB PHONE # (970) 532 2078

DATE RECEIVED IN LABORATORY 11/5/2014 DATE ANALYZED 11/6/2014

COMMENTS: _____

PARAMETER	RESULT	UNITS	ANALYSIS DATE	LABORATORY METHOD
Coliform TOTAL (Verified)		#/100 mL		
Coliform FECAL/E. coli (Verified)		#/100 mL		
Coliform TOTAL (Absent/Present)	ABSENT		11/6/14	24 Colilert
Coliform FECAL/E. coli (Absent/Present)				

LABORATORY: Please call Drinking Water Section with any results other than < 1 or ABSENT.

NT = Not Tested for compound
TNTC = Too Numerous To Count - Please resample
OD = Outdated - Please resample
<1 = Safe valid sample
Present Coliform / E. coli / Fecal detected

#/100 ml = Number of colonies per 100 ml of sample
CG = Confluent Growth - Please resample
LA = Lab Accident - Please resample
Absent = Coliform / E. coli / Fecal not detected

Reviewed & Approved by

Title

Date

MAIL RESULTS TO: CDPHE, WQCD-CADM-B2, 4300 Cherry Creek Drive South, Denver, CO 80246-1530

LABORATORY ANALYTICAL REPORT

Customer 20011350
Meadow Mountain Water
PO Box 354
Allenspark, CO 80510
PWSID: CO 0207504

Invoice Number: 20140633
Received Date & Time: 11/5/2014 9:45AM
Arrival Temperature: 18.8°C

Sample Identification: PLANT

Sample Information:

Sample Date & Time: 11/5/2014 7:30AM

Sampler: Steve Tedford

Volume Sampled: 100ml

Sample Type: Grab

Processing Date & Time: 11/5/2014 10:24AM

Analytical Method: 9223B, IDEXX Colilert® with QuantiTray® 2000

Start Date & Time: 11/5/2014 10:24AM

Amount Analyzed: 100ml

Stop Date & Time: 11/6/2014 10:24AM

Additional Start Date & Time: N/A

Dilution factor: N/A

Additional Stop Date & Time: N/A

Analytical Results:

Analyte Reporting Limit: 1.0

Coliform bacteria: ABSENT

Chlorine Residual: 1.3

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.


Report Approved By


Title

Date

11/19/14