



Colorado Department
of Public Health
and Environment

Haloacetic Acids Certified Laboratory Report Form
WQCD - Drinking Water CAS
4300 Cherry Creek Drive South, Denver, CO 80246-1530
Fax: (303) 758-1398; cdphe.drinkingwater@state.co.us

Revision: 6/13/2014

HAA5

Section I (to be completed by the Public Water Systems only)						Section II (to be completed by Laboratories only)				
Public Water System Information						Laboratory Information				
PWSID#: CO0207504			Facility ID: DS001			Laboratory ID: CO 0015				
System Name: Meadow Mountain Water Company						Laboratory Name: Colorado Analytical Laboratory				
Contact Person: Steve Tedford			Phone #: 303-747-2066			Contact Person: Customer Service		Phone: 303-659-2313		
Comments:						Comments:				

Section III (Supplied or Completed by PWS)			Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Sample Pt ID On Schedule	Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	MCL (ug/L)	Lab MRL (ug/L)	Result (ug/L)
9/4/15	DBP001	DBP001	9/4/15	9/11/15	150904048-01	Monochloroacetic Acid	EPA 552.2	N/A	0.501	1.25
						Monobromoacetic Acid	EPA 552.2	N/A	0.343	BDL
						Dichloroacetic Acid	EPA 552.2	N/A	0.27	33.24
						Trichloroacetic Acid	EPA 552.2	N/A	0.435	16.86
						Dibromoacetic Acid	EPA 552.2	N/A	0.299	BDL
						Total Haloacetic Acids	EPA 552.2	60	N/A	51.35

NT: Not Tested

Lab MRL: Laboratory Minimum Reporting Level

BDL: Below Laboratory MRL. A less than (<) may also used.

ug/L: Micrograms per Liter

MCL: Maximum Contaminant Level

9/17/15

150904048

1/ 1

Y

