

LABORATORY ANALYTICAL REPORT

Customer 20011350
Meadow Mountain Water
PO Box 354
Allenspark, CO 80510
PWSID: CO 0207504

Invoice Number: 20150011
Received Date & Time: 1/7/2015 10:30AM
Arrival Temperature: 17.2°C

Sample Identification: MORRIS	
Sample Information:	
Sample Date & Time: 1/7/2015 8:30AM	Sampler: Steve Tedford
Volume Sampled: 100ml	Sample Type: Grab
Processing Date & Time: 1/7/2015 11:40AM	

Analytical Method: 9223B, IDEXX Colilert® with QuantiTray® 2000

Start Date & Time: 1/7/2015 11:40AM **Amount Analyzed:** 100ml
Stop Date & Time: 1/8/2015 11:40AM

Additional Start Date & Time: N/A
Additional Stop Date & Time: N/A

Dilution factor: N/A

Analytical Results:

Analyte Reporting Limit: 1.0


Coliform bacteria: ABSENT

Chlorine Residual: 0.3

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.



Report Approved By


Title

Date 1/12/15



Colorado Department
of Public Health
and Environment

Individual Bacteriological Certified Laboratory Report Form

Revision: 12/24/2014

WQCD - Drinking Water CAS

4300 Cherry Creek Drive South; Denver, CO 80246-1530

Fax: (303) 758-1398; cdphe.drinkingwater@state.co.us; **Positive Hotline: (303) 692-3308**

Section I (Supplied or Completed by Public Water System)

Public Water System Information

PWS ID: CO 0207504

System Name: MEADOW MOUNTAIN WATER SUPPLY

Contact Person: STEVE TEDFORD

Phone #: 303-747-2066

Comments:

Section II (Supplied or Completed by Certified Laboratory)

Certified Laboratory Information

Laboratory ID: CO 01020

Laboratory Name: CHDIAGNOSTIC & CONSULTING SERVICE INC.

Contact Person: RHONDA DUNCAN

Phone #: 970-532-2078

Comments:

Section III (Supplied or Completed by Public Water System)

Sample Date: 1/7/2015

Collector: STEVE TEDFORD

Section IV (Supplied or Completed by Certified Laboratory)

Lab Analysis Date: 1/8/2015

Analytical Method: 24 COLILERT

Section V (Supplied or Completed by Public Water System)

Sample Type	Sample Time	Facility ID On Schedule	Sample Pt ID On Schedule	Street Address	*Disinfectant Residual	Lab Sample ID	Analyte Name (Code)	Result
RT	8:30 AM	CO0207504	Meadow Mtn Water Supp	PO BOX 354 Allenspark, CO 80510	0.3 mg/L	20150011 (MORRIS)	Total Coliform (3100)	ABSENT
							<i>E. Coli</i> (3014)	ABSENT
							Total Coliform (3100)	
							<i>E. Coli</i> (3014)	
							Total Coliform (3100)	
							<i>E. Coli</i> (3014)	
							Total Coliform (3100)	
							<i>E. Coli</i> (3014)	
							Total Coliform (3100)	
							<i>E. Coli</i> (3014)	
							Total Coliform (3100)	

LABORATORY: Please call Hotline with any PRESENT results

(Total Coliform, *E. Coli*, or Fecal).

SAMPLE TYPE: RT (Routine), RP (Repeat), SP (Special Purpose).

*DISINFECTANT RESIDUAL: Report in mg/L.

Use separate form if samples collected on different dates.

LA: Lab Accident - Please resample.

CG: Confluent Growth - Please resample.

TNTC: Too Numerous To Count - Please resample.

H: Holding time has been exceeded - Please resample.

Present: Coliform / *E. Coli* / Fecal detected.

Absent: Coliform / *E. Coli* / Fecal not detected.

NT: Not Tested.