



Colorado Department
of Public Health
and Environment

Lead and Copper Certified Laboratory Report Form


WQCD – Drinking Water CAS

4300 Cherry Creek Drive South, Denver, CO 80246-1530

Fax: (303) 758-1398; cdphe.drinkingwater@state.co.us

Revision 6/4/13

LCR

Section I (Completed by Public Water System)					Section II (Completed by Certified Laboratory)						
Public Water System Information					Certified Laboratory Information						
PWS ID: CO-0207504		Facility ID: DS001			Laboratory ID:						
System Name: Meadow Mountain Water Company					Laboratory Name: Stewart Environmental Consultants, LLC.						
Contact Person: Steve Tedford		Phone #: 303-747-2066			Contact Person: Michael Glavanovich			Phone #: 970-226-5500			
Comments:					Comments:						
					 Michael A. Glavanovich Laboratory Manager 07/16/13						
					Laboratory Authorized Signature		Printed Name		Title		Date
Section III (Completed by Public Water System)					Section IV (Completed by Certified Laboratory)						
Sample Date	Collector	Sample Pt ID / Address – Location	Lab Receipt Date	Lab Analysis Date	Lab Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MDL (mg/L)	Result (mg/L)	
06/23/13	Steve Tedford	1	06/25/13	07/10/13	S131760934	Copper	EPA 200.7	1.3	0.005	0.303	
						Lead	EPA 200.9	0.015	0.0025	0.038	
06/23/13	Steve Tedford	2	06/25/13	07/10/13	S13176093A	Copper	EPA 200.7	1.3	0.005	0.302	
						Lead	EPA 200.9	0.015	0.0025	BDL	
06/23/13	Steve Tedford	3	06/25/13	07/10/13	S13176093B	Copper	EPA 200.7	1.3	0.005	0.171	
						Lead	EPA 200.9	0.015	0.0025	BDL	
06/23/13	Steve Tedford	4	06/25/13	07/10/13	S13176093C	Copper	EPA 200.7	1.3	0.005	0.233	
						Lead	EPA 200.9	0.015	0.0025	0.006	
06/23/13	Steve Tedford	5	06/25/13	07/10/13	S13176093D	Copper	EPA 200.7	1.3	0.005	0.267	
						Lead	EPA 200.9	0.015	0.0025	0.008	
						Copper		1.3			
						Lead		0.015			