



Lead and Copper Certified Laboratory Report Form
WQCD - Drinking Water CAS
4300 Cherry Creek Drive South, Denver, CO 80246-1530
Fax: (303) 758-1398; cdphe.drinkingwater@state.co.us

Revised 6/13/2014

LCR

Section I (Supplied or Completed by Public Water System)				Section II (Supplied or Completed by Certified Laboratory)						
Public Water System Information				Certified Laboratory Information						
PWSID#: CO0207504		Facility ID: DS001		Laboratory ID: CO 0015						
System Name: Meadow Mountain Water Company				Laboratory Name: Colorado Analytical Laboratory						
Contact Person: Rachel Barkworth			Phone #: 303-747-2066	Contact Person: Customer Service			Phone: 303-659-2313			
Comments:				Comments:						

Section III (Supplied or Completed by Public Water System)			Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Collector	Sample Pt ID / Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
5/21/16	Steve Tedford	1 - Hames	5/23/16	5/25/16	160523051-01	Copper	EPA 200.8	1.3	0.001	0.019
5/21/16	Steve Tedford	1 - Hames	5/23/16	5/25/16	160523051-01	Lead	EPA 200.8	0.015	0.001	0.002
Sample Date	Collector	Sample Pt ID / Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
5/22/16	Steve Tedford	2 - Hill	5/23/16	5/25/16	160523051-02	Copper	EPA 200.8	1.3	0.001	0.039
5/22/16	Steve Tedford	2 - Hill	5/23/16	5/25/16	160523051-02	Lead	EPA 200.8	0.015	0.001	0.002
Sample Date	Collector	Sample Pt ID / Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
5/21/16	Steve Tedford	3 - Brock	5/23/16	5/25/16	160523051-03	Copper	EPA 200.8	1.3	0.001	0.402
5/21/16	Steve Tedford	3 - Brock	5/23/16	5/25/16	160523051-03	Lead	EPA 200.8	0.015	0.001	0.001
Sample Date	Collector	Sample Pt ID / Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
5/23/16	Steve Tedford	4 - Newton	5/23/16	5/25/16	160523051-04	Copper	EPA 200.8	1.3	0.001	0.172
5/23/16	Steve Tedford	4 - Newton	5/23/16	5/25/16	160523051-04	Lead	EPA 200.8	0.015	0.001	BDL
Sample Date	Collector	Sample Pt ID / Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
5/21/16	Steve Tedford	5 - Hans	5/23/16	5/25/16	160523051-05	Copper	EPA 200.8	1.3	0.001	0.164
5/21/16	Steve Tedford	5 - Hans	5/23/16	5/25/16	160523051-05	Lead	EPA 200.8	0.015	0.001	BDL

NT: Not Tested
 Lab MRL: Laboratory Minimum Reporting Level
 BDL: Below Laboratory MRL. A less than (<) may also used.

mg/L: Milligrams per Liter
 AL: Action Level

160523051 Y

1/1

LABORATORIES, INC.

Brighton Lab
240 South Main Street
Brighton, CO 80601

Phone: 303-659-2313
Fax: 303-659-2315

160523051

Page 2 of 2