



Lead and Copper Certified Laboratory Report Form
WQCD - Drinking Water CAS
4300 Cherry Creek Drive South, Denver, CO 80246-1530
Fax: (303) 758-1398; cdphe.drinkingwater@state.co.us

Revised 6/13/2014

LCR

Section I (Supplied or Completed by Public Water System)			Section II (Supplied or Completed by Certified Laboratory)							
Public Water System Information			Certified Laboratory Information							
PWSID#: CO0207504		Facility ID: DS001	Laboratory ID: CO 0015							
System Name: Meadow Mtn Water Supply			Laboratory Name: Colorado Analytical Laboratory							
Contact Person: Steve Tedford		Phone #: 303-747-2066	Contact Person: Customer Service				Phone: 303-659-2313			
Comments:			Comments:							
Section III (Supplied or Completed by Public Water System)			Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Collector	Sample Pt ID / Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
7/10/16		Hill	7/11/16	7/15/16	160711001-01	Copper	EPA 200.8	1.3	0.001	0.026
7/10/16		Hill	7/11/16	7/15/16	160711001-01	Lead	EPA 200.8	0.015	0.001	BDL

NT: Not Tested
Lab MRL: Laboratory Minimum Reporting Level
BDL: Below Laboratory MRL. A less than (<) may also used.

mg/L: Milligrams per Liter
AL: Action Level

160711001 Y

1/1

Colorado
Analytical

LABORATORIES, INC.

Brighton Lab
240 South Main Street
Brighton, CO 80601

Lakewood Lab
12860 W. Cedar Dr. Suite 100A
Lakewood CO 80228

Phone: 303-659-2313
Fax: 303-659-2315

www.coloradolab.com

Page 2 of 2