



Lead and Copper Certified Laboratory Report Form
WQCD - Drinking Water CAS
4300 Cherry Creek Drive South, Denver, CO 80246-1530
Fax: (303) 758-1398; cdphe.drinkingwater@state.co.us

Revised 6/13/2014

LCR

Section I (Supplied or Completed by Public Water System)		Section II (Supplied or Completed by Certified Laboratory)	
Public Water System Information		Certified Laboratory Information	
PWSID#: CO0207504	Facility ID: DS001	Laboratory ID: CO 0015	
System Name: Meadow Mtn Water Supply		Laboratory Name: Colorado Analytical Laboratory	
Contact Person: Steve Tedford	Phone #: 303-747-2066	Contact Person: Customer Service	Phone: 303-659-2313
Comments:		Comments:	

Section III (Supplied or Completed by Public Water System)			Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Collector	Sample Pt ID / Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
8/9/16		Newton	8/9/16	8/16/16	160809059-01	Copper	EPA 200.8	1.3	0.001	0.365
8/9/16		Newton	8/9/16	8/16/16	160809059-01	Lead	EPA 200.8	0.015	0.001	0.002
Sample Date	Collector	Sample Pt ID / Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
8/9/16		Hames	8/9/16	8/16/16	160809059-02	Copper	EPA 200.8	1.3	0.001	0.014
8/9/16		Hames	8/9/16	8/16/16	160809059-02	Lead	EPA 200.8	0.015	0.001	0.014
Sample Date	Collector	Sample Pt ID / Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
8/9/16		Brock	8/9/16	8/16/16	160809059-03	Copper	EPA 200.8	1.3	0.001	0.342
8/9/16		Brock	8/9/16	8/16/16	160809059-03	Lead	EPA 200.8	0.015	0.001	0.001
Sample Date	Collector	Sample Pt ID / Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
8/9/16		Hans	8/9/16	8/16/16	160809059-04	Copper	EPA 200.8	1.3	0.001	0.059
8/9/16		Hans	8/9/16	8/16/16	160809059-04	Lead	EPA 200.8	0.015	0.001	BDL

NT: Not Tested
 Lab MRL: Laboratory Minimum Reporting Level
 BDL: Below Laboratory MRL. A less than (<) may also used.

mg/L: Milligrams per Liter
 AL: Action Level

160809059 Y

Colorado
Analytical

LABORATORIES, INC.

www.coloradolab.com

Subcontract Analyses

Page 2 of 2

Instructions:

Seals Present	Yes	No	Headspace	Yes	No
	☐	☒		☐	☐

Sample Pres Yes ☐ No ☒