



Lead and Copper Certified Laboratory Report Form
WQCD - Drinking Water CAS
4300 Cherry Creek Drive South, Denver, CO 80246-1530
Fax: (303) 758-1398; cdphe.drinkingwater@state.co.us

Revised 6/13/2014

LCR

Section I (Supplied or Completed by Public Water System)		Section II (Supplied or Completed by Certified Laboratory)	
Public Water System Information		Certified Laboratory Information	
PWSID#: CO0207504	Facility ID: DS001	Laboratory ID: CO 0015	
System Name: Meadow Mtn Water Supply		Laboratory Name: Colorado Analytical Laboratory	
Contact Person: Steve Tedford	Phone #: 303-747-2066	Contact Person: Customer Service	Phone: 303-659-2313
Comments:		Comments:	

Section III (Supplied or Completed by Public Water System)			Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Collector	Sample Pt ID / Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
4/26/17	Steve Tedford	Hames	4/26/17	5/1/17	170426072-01	Copper	EPA 200.8	1.3	0.001	0.011
4/26/17	Steve Tedford	Hames	4/26/17	5/1/17	170426072-01	Lead	EPA 200.8	0.015	0.001	0.004
Sample Date	Collector	Sample Pt ID / Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
4/26/17	Steve Tedford	Newton	4/26/17	5/1/17	170426072-02	Copper	EPA 200.8	1.3	0.001	0.200
4/26/17	Steve Tedford	Newton	4/26/17	5/1/17	170426072-02	Lead	EPA 200.8	0.015	0.001	BDL
Sample Date	Collector	Sample Pt ID / Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
4/26/17	Steve Tedford	Hans	4/26/17	5/1/17	170426072-03	Copper	EPA 200.8	1.3	0.001	0.028
4/26/17	Steve Tedford	Hans	4/26/17	5/1/17	170426072-03	Lead	EPA 200.8	0.015	0.001	BDL
Sample Date	Collector	Sample Pt ID / Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
4/26/17	Steve Tedford	Brock	4/26/17	5/1/17	170426072-04	Copper	EPA 200.8	1.3	0.001	0.070
4/26/17	Steve Tedford	Brock	4/26/17	5/1/17	170426072-04	Lead	EPA 200.8	0.015	0.001	BDL

NT: Not Tested
 Lab MRL: Laboratory Minimum Reporting Level
 BDL: Below Laboratory MRL. A less than (<) may also used.

mg/L: Milligrams per Liter
 AL: Action Level

170426072 M

1/1

Drinking Water Chain of Custody



LABORATORIES, INC.

Brighton Lab
240 South Main Street
Brighton, CO 80601

Lakewood Lab
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313
Fax: 303-659-2315

www.coloradolab.com

Report To Information		Bill To Information (If different from report to)		State Form / Project Information	
Company Name: <u>NEADOW MOUNTAIN WATER</u>		Contact Name: <u>NEADOW MOUNTAIN WATER</u>		PWSID: <u>207504</u>	
Contact Name: <u>PO. Box 162</u>		Address: <u>PO. Box 162</u>		System Name: <u>NEADOW MOUNTAIN WATER</u>	
Address: <u>State CO Zip 80510</u>		City: <u>State CO Zip 80510</u>		City: <u>State CO Zip 80510</u>	
Phone: <u>Fax:</u>		Phone: <u>Fax:</u>		County: <u>Beulah</u>	
Email: <u>Sample Name: <u>Stu</u></u>		Email: <u>Send Forms to State: Yes ☒ No ☐</u>		Compliance Samples: Yes ☒ No ☐	

CAL Task No.
170426072

PHASE I, II, V Drinking Water Analyses (check analysis)

Subcontract Analyses

ARF		Client Sample ID / EP Code	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothall	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226	Radium 228	Radon	Uranium
Date	Time																												
4-26-17	8:15A	10A17S	1																										
"	"	NEADOW	1																										
"	"	HANS	1																										
"	"	BODICE	1																										
"	"	4.05V4	4																										
"	"	4.1	2																										
"	"	4.3	3																										
"	"	4.4	4																										
Instructions:		34-VOC Blank																											
Relinquished By: <u>Stu</u>		Date/Time: <u>4-26-17</u>		Received By: <u>Hand</u>		Date/Time: <u>4/26/17</u>		Relinquished Via: <u>Hand</u>		C/S Charge: <u>Yes</u>		Temp: <u>4.0</u>		C/S Charge: <u>Yes</u>		Temp: <u>4.0</u>		Received By: <u>Hand</u>		Date/Time: <u>4/26/17</u>		Sample Pres. Yes ☒ No ☐		Date/Time: <u>4/26/17</u>		Sample Pres. Yes ☒ No ☐			