

## LABORATORY ANALYTICAL REPORT

**Customer** 20011350  
Meadow Mountain Water  
PO Box 354  
Allenspark, CO 80510  
**PWSID:** CO 0207504

**Invoice Number:** 20170515  
**Received Date & Time:** 5/2/2017 10:25AM  
**Arrival Temperature:** 17.8°C

<b>Sample Identification:</b> MORRIS	
<b>Sample Information:</b>	
<b>Sample Date &amp; Time:</b> 5/2/2017 8:05AM	<b>Sampler:</b> Steve Tedford
<b>Volume Sampled:</b> 100 ml	<b>Sample Type:</b> Grab
<b>Processing Date &amp; Time:</b> 5/2/2017 10:32AM	

**Analytical Method:** 9223B, IDEXX Colilert® with QuantiTray® 2000

**Start Date & Time:** 5/2/2017 10:32AM

**Amount Analyzed:** 100 ml

**Stop Date & Time:** 5/3/2017 10:42AM

**Additional Start Date & Time:** N/A

**Dilution factor:** N/A

**Additional Stop Date & Time:** N/A



### Analytical Results:

**Analyte Reporting Limit:** 1.0

**Coliform bacteria:** ABSENT

**Chlorine Residual:** 0.7

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.

  
**Report Approved By**  
  
**Title** **Date** 5/23/17