

LABORATORY ANALYTICAL REPORT

Customer 20011350
Meadow Mountain Water
PO Box 354
Allenspark, CO 80510
PWSID: CO 0207504

Invoice Number: 20170691
Received Date & Time: 6/12/2017 11:00AM
Arrival Temperature: 25.6°C

Sample Identification: MORRIS	
Sample Information: SOURCE: Stream/River	
Sample Date & Time: 6/12/2017 6:50AM	Sampler: Steve Tedford
Volume Sampled: 100 ml	Sample Type: Grab
Processing Date & Time: 6/12/2017 11:39AM	

Analytical Method: 9223B, IDEXX Colilert® with QuantiTray® 2000

Start Date & Time: 6/12/2017 11:39AM **Amount Analyzed:** 100 ml
Stop Date & Time: 6/13/2017 11:42AM

Additional Start Date & Time: N/A **Dilution factor:** N/A
Additional Stop Date & Time: N/A

Analytical Results:

Analyte Reporting Limit: 1.0

Coliform bacteria: ABSENT

Chlorine Residual: 0.7

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.


Report Approved By


Title **Date**

CH Diagnostic Consulting Service, Inc.
512 5th Street, Berthoud CO 80513
PH: (970) 532 2078 FX: (970) 532 3358