LABORATORY ANALYTICAL REPORT

20011350 Customer

Meadow Mountain Water

PO Box 354

Allenspark, CO 80510 PWSID: CO 0207504

Invoice Number: 20171029

Received Date & Time: 9/12/2017 11:50AM

Arrival Temperature: 19.8°C

Sample Identification: NEWTON

Sample Information: unrec.

Sample Date & Time: 9/12/2017 7:45AM Sampler: Steve Tedford

Volume Sampled: 100 ml Sample Type: Grab

Processing Date & Time: 9/12/2017 12:18PM

Analytical Method: 9223B, IDEXX Collect® with QuantiTray® 2000

Start Date & Time: 9/12/2017 12:18PM

Amount Analyzed: 100 ml

Stop Date & Time: 9/13/2017 12:51PM

Additional Start Date & Time: N/A

Dilution factor: N/A

Additional Stop Date & Time: N/A

Analytical Results:

Analyte Reporting Limit: 1.0

Coliform bacteria: ABSENT

Chlorine Residual:

0.3

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.

CH Diagnostic Consulting Service, Inc. 512 5th Street, Berthoud CO 80513 PH: (970) 532 2078 FX: (970) 532 3358