

## LABORATORY ANALYTICAL REPORT

Customer 20011350  
Meadow Mountain Water  
PO Box 354  
Allenspark, CO 80510  
PWSID: CO 0207504

Invoice Number: 20171264  
Received Date & Time: 11/14/2017 11:45AM  
Arrival Temperature: 18.5°C

Sample Identification: NEWTON-RTOR-Routine #2

Sample Information: unrec.

Sample Date & Time: 11/14/2017 8:20AM

Sampler: Steve Tedford

Volume Sampled: 100 ml

Sample Type: Grab

Processing Date & Time: 11/14/2017 12:02PM

Analytical Method: 9223B, IDEXX Colilert® with QuantiTray® 2000

Start Date & Time: 11/14/2017 12:02PM

Amount Analyzed: 100 ml

Stop Date & Time: 11/15/2017 12:11PM

Additional Start Date & Time: N/A

Dilution factor: N/A

Additional Stop Date & Time: N/A


### Analytical Results:

Analyte Reporting Limit: 1.0

Coliform bacteria: ABSENT

Chlorine Residual: 0.5

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.

  
Report Approved By

  
Title Date