



Certificate of Analysis

Meadow Mt. Water Supply Co.

PO Box 354

CustID# 10757

Allenspark CO

Attn: Andrew Griffiths

Date Received: 6/14/2018

Date Reported: 6/21/2018

Location Name: CRS001

Batch No: 11683



Sample Date: 6/13/2018

Sample Time: 6:05:00 AM

Sample ID: B181651244



Client Sample ID: CO0207504

Matrix: Water

Analysis	Results	Units	Limit of Quantitation	Method	Invoice
Coliform, E-coli	< 1	MPN	1 MPN	SM 9223	
Coliform, Total	16.1	MPN	1 MPN	SM 9223	

Our Company makes no warranty except that the analysis has been made upon the samples received in accordance with generally accepted testing laboratory principles and practices and by methods approved by the U.S. EPA and State Department of Health. The results of the analysis may not be characteristic of the whole from which the sample was taken.

Results Approved by:

Laboratory/Water Quality Supervisor

Please contact Water Quality Supervisor at 970-577-3624 or via email dcallahan@estes.org if you have any questions regarding the testing above.

Test Note:



ESTES PARK
COLORADO

Town of Estes Park
Water Department
Chain of Custody

System Information

PWSID#: 600135257

Address: Box

Contact: ALLENS PARK CO SOS/D

Phone: (303) 477-2715

e-mail: andy.pearl@townofestes.net

Billing Information (if different):

Company: MEADOW MTD. WATER SUPPLY COMPANY

Address: _____

Contact Person: _____

Phone: _____

e-mail: _____

State Form Information:

State Form Required ☒ Yes ☐ No

Compliance Samples ☒ Yes ☐ No

Submit Forms to State ☒ Yes ☐ No

Water Supply:

Public/Community ☒ Private ☐

Samplers Signature: A. Sample

Sample Location or ID	Date	Time	Analysis:	
CRS 001	6/13/18	6:05a	☐ Total/E. coli Enum	Other: <u>LT2</u> Cl2: <u>RAW</u>
			☐ Total/E. coli Enum	Other: _____ Cl2: _____
			☐ Total/E. coli Enum	Other: _____ Cl2: _____
			☐ Total/E. coli Enum	Other: _____ Cl2: _____
			☐ Total/E. coli Enum	Other: _____ Cl2: _____
			☐ Total/E. coli Enum	Other: _____ Cl2: _____
			☐ Total/E. coli Enum	Other: _____ Cl2: _____
			☐ Total/E. coli Enum	Other: _____ Cl2: _____
			☐ Total/E. coli Enum	Other: _____ Cl2: _____

Relinquished By: A. Sample

Date: 6/13/18

Time: 10:50a

Received By: Mark Sadowski

Relinquished By: _____

Date: _____

Time: _____

Received By: _____

Notes/Remarks:

B181651244

Notice of sample invalidation: samples taken for microbiological determination will be invalidated if: (1) received in the laboratory more than 24 hours after collection, (2) a presence of disinfectant is noticed, (3) evidence of freezing, (4) use of unapproved containers, (5) sample volume < 100 ml, (6) presence of interfering contaminants, (7) sample temperature > 10°C unless collection is within 2 hours of receipt in the laboratory.



Certificate of Analysis

Meadow Mt. Water Supply Co.

PO Box 354

CustID# 10757

Allenspark CO

Attn: Andrew Griffiths

Date Received: 6/27/2018

Date Reported: 6/29/2018

Location Name: CRS001

Batch No: 11709



Sample Date: 6/27/2018

Sample Time: 2:30:00 PM

Sample ID: B181800907



Client Sample ID: CO0207504

Matrix: Water

Analysis	Results	Units	Limit of Quantitation	Method	Invoice
Coliform, E-coli	< 1	MPN	1 MPN	SM 9223	
Coliform, Total	21.3	MPN	1 MPN	SM 9223	

Our Company makes no warranty except that the analysis has been made upon the samples received in accordance with generally accepted testing laboratory principles and practices and by methods approved by the U.S. EPA and State Department of Health. The results of the analysis may not be characteristic of the whole from which the sample was taken.

Results Approved by:

Laboratory/Water Quality Supervisor

Please contact Water Quality Supervisor at 970-577-3624 or via email dcallahan@estes.org if you have any questions regarding the testing above.

Test Note:



ESTES PARK
COLORADO

Town of Estes Park
Water Department
Chain of Custody

Client/Billing Information:

Company: MEADOW MOUNTAIN WATER SUPPLY CO System Information: CO 207504
Address: Box 162 ~~Box 162~~ ALDEN PARK CANYON PWSID#
Contact: ANDREW GRIFFITHS System Address:
Phone: 303-247-2715 e-mail: andrew@meadowmountainwater.com Contact Person:
e-mail:

State Form Information:

State Form Required ☒ Yes ☐ No
Compliance Samples ☒ Yes ☐ No
Submit Forms to State ☒ Yes ☐ No

Water Supply:

Public/Community ☒ Private ☐
Samplers Signature: AS [Signature]

Sample Location or ID	Date	Time	Analysis:	
CRS 001	6/27/18	7:30p	☐ Total/E. coli Enum	☐ Other: <u>CT2</u> <u>RAW</u>
			☐ BacT (P/A)	☐ Other: <u> </u>
			☐ Total/E. coli Enum	☐ Other: <u> </u>
			☐ BacT (P/A)	☐ Other: <u> </u>
			☐ Total/E. coli Enum	☐ Other: <u> </u>
			☐ BacT (P/A)	☐ Other: <u> </u>
			☐ Total/E. coli Enum	☐ Other: <u> </u>
			☐ BacT (P/A)	☐ Other: <u> </u>
			☐ Total/E. coli Enum	☐ Other: <u> </u>
			☐ BacT (P/A)	☐ Other: <u> </u>
			☐ Total/E. coli Enum	☐ Other: <u> </u>
			☐ BacT (P/A)	☐ Other: <u> </u>
			☐ Total/E. coli Enum	☐ Other: <u> </u>
			☐ BacT (P/A)	☐ Other: <u> </u>
			☐ Total/E. coli Enum	☐ Other: <u> </u>

Relinquished By:

Date: 6/27/18

Time: 4:10p

Received By: Webb Callahan

Relinquished By:

Date:

Time:

Received By:

Notes/Remarks:

B181800907

1. Enable Macros.

1. Enable Macros.
2. Enter sample results starting in the row below the column titles.

3. Press the button.

4. Name the CSV file.

5. Select a folder to save the CSV file to.

Note: OK to change column order, but not column

[illegible]