



Certificate of Analysis

Meadow Mt. Water Supply Co.

PO Box ~~354~~ 162

CustID# 10757

Allenspark CO

Attn: Andrew Griffiths

Date Received: 8/8/2018

Date Reported: 8/10/2018

Location Name: CRS001

Sample Date: 8/8/2018

Sample Time: 11:00:00 AM

Client Sample ID: CO0207504

Matrix: Water

Batch No: 11773



Sample ID: B182201405



Analysis	Results	Units	Limit of Quantitation	Method	Invoice
Coliform, E-coli	3	MPN	1 MPN	SM 9223	
Coliform, Total	93.3	MPN	1 MPN	SM 9223	

Our Company makes no warranty except that the analysis has been made upon the samples received in accordance with generally accepted testing laboratory principles and practices and by methods approved by the U.S. EPA and State Department of Health. The results of the analysis may not be characteristic of the whole from which the sample was taken.

Results Approved by:

Laboratory/Water Quality Supervisor

Please contact Water Quality Supervisor at 970-577-3624 or via email dcallahan@estes.org if you have any questions regarding the testing above.

Test Note:



ESTES PARK
COLORADO

Town of Estes Park
Water Department
Chain of Custody

Client/Billing Information:

Company: MEADOW MTD. WATER SUPPLY COMPANY
Address: Box 162 ALLENSPARK CO 80510
Contact: ANDREW GRIFFITHS
Phone: (303) 747-2715 e-mail: andrew@waterlink.net

System Information:

PWSID# C0207504
System Address: _____
Contact Person: _____
Phone: _____ e-mail: _____

State Form Information:

State Form Required ☒ Yes
Compliance Samples ☒ Yes
Submit Forms to State ☒ Yes

☒ Yes
☒ Yes
☒ Yes

No
No
No

Water Supply:

Public/Community ☒ Private ☐

Samplers Signature:

[Signature]

Sample Location or ID	Date	Time	Analysis:	
INTAKE CRS001	8/8/18	11:00a	☒ Total/E. coli Enum	LT2 CL2: RAW
			☐ BacT (P/A)	Other: CL2: _____
			☐ BacT (P/A)	Other: CL2: _____
			☐ BacT (P/A)	Other: CL2: _____
			☐ BacT (P/A)	Other: CL2: _____
			☐ BacT (P/A)	Other: CL2: _____
			☐ BacT (P/A)	Other: CL2: _____
			☐ BacT (P/A)	Other: CL2: _____
			☐ BacT (P/A)	Other: CL2: _____
			☐ BacT (P/A)	Other: CL2: _____
			☐ BacT (P/A)	Other: CL2: _____

Relinquished By: [Signature]

Date: 8/8/18 Time: 1:30

Relinquished By: [Signature]

Date: 8/8/18 Time: 1:30

Notes/Remarks:

B 182201405



Certificate of Analysis

Meadow Mt. Water Supply Co.
PO Box 162
CustID# 10757
Allenspark CO
Attn: Andrew Griffiths

Date Received: 8/21/2018
Date Reported: 8/23/2018

Location Name: CRS001

Batch No: 11803

Sample Date: 8/21/2018 Sample Time: 11:45:00 AM



Client Sample ID: CO0207504

Sample ID: B182341503

Matrix: Water



Analysis	Results	Units	Limit of Quantitation	Method	Invoice
Coliform, E-coli	< 1	MPN	1 MPN	SM 9223	
Coliform, Total	206.4	MPN	1 MPN	SM 9223	

Our Company makes no warranty except that the analysis has been made upon the samples received in accordance with generally accepted testing laboratory principles and practices and by methods approved by the U.S. EPA and State Department of Health. The results of the analysis may not be characteristic of the whole from which the sample was taken.

Results Approved by:

Laboratory/Water Quality Supervisor

Please contact Water Quality Supervisor at 970-577-3624 or via email dcallahan@estes.org if you have any questions regarding the testing above.

Test Note:



**Town of Estes Park
Water Department
Chain of Custody**

System Information		Billing Information (if different):	
PWSID#:	CO 207504	Company:	MEADOW Mtn. WATER SUPPLY CO.
Address:	BOX 162, ALLENSPARK, CO 80510	Address:	
Contact:	ANDREW GRIFFITHS	Contact Person:	
Phone:	(303) 247-2715 e-mail: andygriff@waterbirds.net	Phone:	
		e-mail:	

State Form Information:			
State Form Required	☒ Yes	☐ No	☐
Compliance Samples	☒ Yes	☐ No	☐
Submit Forms to State	☒ Yes	☐ No	☐

[illegible]

Relinquished By:	Date:	Time:	Received By:
<i>[Signature]</i>	8/21/18	3:30	<i>[Signature]</i>
Relinquished By:	Date:	Time:	Received By:

Notes/Remarks: B182341503

Notice of sample invalidation: samples taken for microbiological determination will be invalidated if: (1) received in the laboratory more than 24 hours after collection, (2) a presence of disinfectant is noticed, (3) evidence of freezing, (4) use of unapproved containers, (5) sample volume < 100 ml, (6) presence of interfering contaminants, (7) sample temperature >10°C unless collection is within 2 hours of receipt in the laboratory.

1. Enable Macros.

1. Enable Macros.
2. Enter sample results starting in the row below the column titles.

3. Press the

button.

4. Name the CSV file.

4. Name the CSV file.
5. Select a folder to save the CSV file to.

Note: OK to change column order, but not column

[illegible]