



Certificate of Analysis

Meadow Mt. Water Supply Co.

PO Box 162

CustID# 10757

Allenspark CO

Attn: Andrew Griffiths

Date Received: 10/3/2018

Date Reported: 10/4/2018

Location Name: CRS001

Sample Date: 10/3/2018

Sample Time: 12:10:00 PM

Client Sample ID:

Matrix: Water

Batch No: 11862



Sample ID: B182771325



Analysis	Results	Units	Limit of Quantitation	Method	Invoice
Coliform, E-coli	< 1	MPN	1 MPN	SM 9223	
Coliform, Total	62	MPN	1 MPN	SM 9223	

Our Company makes no warranty except that the analysis has been made upon the samples received in accordance with generally accepted testing laboratory principles and practices and by methods approved by the U.S. EPA and State Department of Health. The results of the analysis may not be characteristic of the whole from which the sample was taken.

Results Approved by:

Laboratory/Water Quality Supervisor

Please contact Water Quality Supervisor at 970-577-3624 or via email dcallahan@estes.org if you have any questions regarding the testing above.

Test Note:



ESTES PARK
COLORADO

Town of Estes Park
Water Department
Chain of Custody

System Information

PWSID#: CO 207504
Address: Box 162 ALLENSPARK CO 80510
Contact: ANDREW GRIFFITHS
Phone: 303-741-2715 e-mail: andrew.g@townofestes.org
Billing Information (if different):
Company: Meadow Mtn. Water Supply Co
Address: _____
Contact Person: _____ e-mail: _____

State Form Information:

State Form Required ☒ Yes ☐ No
Compliance Samples ☒ Yes ☐ No
Submit Forms to State ☒ Yes ☐ No

Water Supply:

Public/Community ☒ Private ☐

Samplers Signature: _____

Sample Location or ID

Date

Time

Analysis:

CRS001	10/3/15	12:10	BacT (P/A)	☐	Total/E. coli Enum	☐	Other: <u>CT2</u>	Cl2: <u>RAW</u>
			BacT (P/A)	☐	Total/E. coli Enum	☐	Other: _____	Cl2: _____
			BacT (P/A)	☐	Total/E. coli Enum	☐	Other: _____	Cl2: _____
			BacT (P/A)	☐	Total/E. coli Enum	☐	Other: _____	Cl2: _____
			BacT (P/A)	☐	Total/E. coli Enum	☐	Other: _____	Cl2: _____
			BacT (P/A)	☐	Total/E. coli Enum	☐	Other: _____	Cl2: _____
			BacT (P/A)	☐	Total/E. coli Enum	☐	Other: _____	Cl2: _____
			BacT (P/A)	☐	Total/E. coli Enum	☐	Other: _____	Cl2: _____

Relinquished By: _____

Date: _____

Time: _____

Received By: _____

Date: _____

Time: _____

Notes/Remarks:

B182771325

Notice of sample invalidation: samples taken for microbiological determination will be invalidated if: (1) received in the laboratory more than 24 hours after collection, (2) a presence of disinfectant is noticed, (3) evidence of freezing, (4) use of unapproved containers, (5) sample volume < 100 ml, (6) presence of interfering contaminants, (7) sample temperature > 10° C unless collection is within 2 hours of receipt in the laboratory.



Certificate of Analysis

Meadow Mt. Water Supply Co.

PO Box 162

CustID# 10757

Allenspark CO

Attn: Andrew Griffiths

Date Received: 10/15/2018

Date Reported: 10/16/2018

Location Name: CRS001

Sample Date: 10/15/2018

Sample Time: 11:30:00 AM

Client Sample ID: CO0207504

Matrix: Water

Batch No: 11873



Sample ID: B182890813



Analysis	Results	Units	Limit of Quantitation	Method	Invoice
Coliform, E-coli	1	MPN	1 MPN	SM 9223	
Coliform, Total	34.5	MPN	1 MPN	SM 9223	

Our Company makes no warranty except that the analysis has been made upon the samples received in accordance with generally accepted testing laboratory principles and practices and by methods approved by the U.S. EPA and State Department of Health. The results of the analysis may not be characteristic of the whole from which the sample was taken.

Results Approved by:

Laboratory/Water Quality Supervisor

Please contact Water Quality Supervisor at 970-577-3624 or via email dcallahan@estes.org if you have any questions regarding the testing above.

Test Note:



ESTES PARK
COLORADO

Town of Estes Park
Water Department
Chain of Custody

System Information

PWSID#:

Co 207504

Address:

Box 162 ALLENSTADT CO 80510

Contact:

ANDREW GRIFFITHS

Phone:

(303) 747-2715

e-mail: andgriffs@allenstadt.net

Billing Information (if different):

Company:

MEADOW MTR. WATER SUPPLY CO

Address:

Contact Person:

Phone:

e-mail:

State Form Information:

State Form Required

Yes ☒ No ☐

Compliance Samples

Yes ☒ No ☐

Submit Forms to State

Yes ☒ No ☐

Water Supply:

Public/Community ☒

Private ☐

Samplers Signature: A. Griffiths

Sample Location or ID

Date

Time

Analysis:

RAW INTAKE CR5001

10/15/18

11:30

BacT (P/A)

☐

Total/E. coli Enum

☐

Other: LTZ

Cl2: RAW

BacT (P/A)

☐

Total/E. coli Enum

☐

Other:

Cl2:

BacT (P/A)

☐

Total/E. coli Enum

☐

Other:

Cl2:

BacT (P/A)

☐

Total/E. coli Enum

☐

Other:

Cl2:

BacT (P/A)

☐

Total/E. coli Enum

☐

Other:

Cl2:

BacT (P/A)

☐

Total/E. coli Enum

☐

Other:

Cl2:

Relinquished By:

M. Collier

Date:

10/15/18

Time:

1:05 PM

Received By:

Allen Stadthaus

Received By:

Received By:

Notes/Remarks:

B182 890813

Notice of sample invalidation: samples taken for microbiological determination will be invalidated if: (1) received in the laboratory more than 24 hours after collection, (2) a presence of disinfectant is noticed, (3) evidence of freezing, (4) use of unapproved containers, (5) sample volume < 100 ml, (6) presence of interfering contaminants, (7) sample temperature > 10° C unless collection is within 2 hours of receipt in the laboratory.

Create CSV File Instructions - Version

1. Enable Macros.
2. Enter sample results starting in the row below the column titles.
3. Press the button.

4. Name the CSV file.
5. Select a folder to save the CSV file to.

Note: OK to change column order, but not column

[illegible]