

LABORATORY ANALYTICAL REPORT

Customer 20011350
Meadow Mountain Water
PO Box 354
Allenspark, CO 80510
PWSID: CO 0207504

Invoice Number: 20180341
Received Date & Time: 4/2/2018 12:22PM
Arrival Temperature: 9.7°C

Sample Identification: Morris-RTOR-Routine #1

Sample Information: unrec.

Sample Date & Time: 4/2/2018 9:30AM

Sampler: Steve Tedford

Volume Sampled: 100 ml

Sample Type: Grab

Processing Date & Time: 4/2/2018 12:30PM

Analytical Method: 9223B, IDEXX Colilert® with QuantiTray® 2000

Start Date & Time: 4/2/2018 12:30PM

Amount Analyzed: 100 ml

Stop Date & Time: 4/3/2018 12:31PM

Additional Start Date & Time: N/A

Dilution factor: N/A

Additional Stop Date & Time: N/A

Analytical Results:


Analyte Reporting Limit: 1.0

Coliform bacteria: ABSENT

Chlorine Residual: 0.5

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.


Report Approved By


Title Date