

LABORATORY ANALYTICAL REPORT

Customer 20011350
Meadow Mountain Water
PO Box 354
Allenspark, CO 80510
PWSID: CO 0207504

Invoice Number: 20180643
Received Date & Time: 6/1/2018 3:00PM
Arrival Temperature: 18.2°C

Sample Identification: NEWTON-RTOR-Routine #2

Sample Information:

Sample Date & Time: 6/1/2018 7:30AM

Sampler: Steve Tedford

Volume Sampled: 100 ml

Sample Type: Grab

Processing Date & Time: 6/1/2018 3:17PM

Analytical Method: 9223B, IDEXX Colilert® with QuantiTray® 2000

Start Date & Time: 6/1/2018 3:17PM

Amount Analyzed: 100 ml

Stop Date & Time: 6/2/2018 3:24PM

Additional Start Date & Time: N/A

Dilution factor: N/A

Additional Stop Date & Time: N/A

Analytical Results:

Analyte Reporting Limit: 1.0

Coliform bacteria: ABSENT

Chlorine Residual: 0.5

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.


Report Approved By


Title

Date

CH Diagnostic Consulting Service, Inc.
512 5th Street, Berthoud CO 80513
PH: (970) 532 2078 FX: (970) 532 3358