

## LABORATORY ANALYTICAL REPORT

**Customer** 20011350  
Meadow Mountain Water  
PO Box 354  
Allenspark, CO 80510  
**PWSID: CO 0207504**

**Invoice Number:** 20180957  
**Received Date & Time:** 9/10/2018 11:00AM  
**Arrival Temperature:** 18.2°C

**Sample Identification:** MORRIS-RTOR-Routine #1

**Sample Information:**

**Sample Date & Time:** 9/10/2018 6:15AM

**Sampler:** Steve Tedford

**Volume Sampled:** 100 ml

**Sample Type:** Grab

**Processing Date & Time:** 9/10/2018 11:12AM

**Analytical Method:** 9223B, IDEXX Colilert® with QuantiTray® 2000

**Start Date & Time:** 9/10/2018 11:12AM

**Amount Analyzed:** 100 ml

**Stop Date & Time:** 9/11/2018 11:21AM

**Additional Start Date & Time:** N/A

**Dilution factor:** N/A

**Additional Stop Date & Time:** N/A

**Analytical Results:**

**Analyte Reporting Limit:** 1.0

**Coliform bacteria:** ABSENT

**Chlorine Residual:** 0.6

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.

  
Report Approved By

Title

Date

CH Diagnostic Consulting Service, Inc.  
512 5th Street, Berthoud CO 80513  
PH: (970) 532 2078 FX: (970) 532 3358