



Certificate of Analysis

Meadow Mt. Water Supply Co.

PO Box 162

CustID# 10757

Allenspark CO

Attn: Andrew Griffiths

Date Received: 11/6/2018

Date Reported: 11/8/2018

Location Name: Meadow Mountain #3

Sample Date: 11/6/2018

Sample Time: 10:00:00 AM

Client Sample ID: CO0207504

Matrix: Water

Batch No: 11895



Sample ID: B183101448



Analysis	Results	Units	Limit of Quantitation	Method	Invoice
BacT - Total	Absent	P / A	1 P / A	SM 9223	
BacT-Ecoli	Absent	P / A	1 P / A	SM 9223	
Chlorine, Free	0.4	mg/L	0.08 mg/L	SM 4500-Cl D	

Our Company makes no warranty except that the analysis has been made upon the samples received in accordance with generally accepted testing laboratory principles and practices and by methods approved by the U.S. EPA and State Department of Health. The results of the analysis may not be characteristic of the whole from which the sample was taken.

Results Approved by:

Laboratory/Water Quality Supervisor

Please contact Water Quality Supervisor at 970-577-3624 or via email dcallahan@estes.org if you have any questions regarding the testing above.

Test Note:



ESTES PARK
COLORADO

Town of Estes Park
Water Department
Chain of Custody

System Information

PWSID#:

Co 207504

Address:

Box 162, ALENSPARK CO, 80510

Contact:

ANDREW GRIFFITHS

Phone:

303-747-2715

e-mail: andy@estepark.net

Billing Information (if different):

Company:

Meadow Mountain Water Supply Co.

Address:

Contact Person:

Phone:

e-mail:

State Form Information:

State Form Required

Yes

☒

No

Compliance Samples

Yes

☒

No

Submit Forms to State

Yes

☒

No

Water Supply:

Public/Community

☒

Private

☐

Samplers Signature:

A. Griffiths

Sample Location or ID

Date

Time

Analysis:

*3 RICH

11/6/18

10:00a

BacT (P/A)

☒

Total/E. coli Enum

☐

Other:

CI2: 0.4

BacT (P/A)

☐

Total/E. coli Enum

☐

Other:

CI2:

BacT (P/A)

☐

Total/E. coli Enum

☐

Other:

CI2:

BacT (P/A)

☐

Total/E. coli Enum

☐

Other:

CI2:

BacT (P/A)

☐

Total/E. coli Enum

☐

Other:

CI2:

BacT (P/A)

☐

Total/E. coli Enum

☐

Other:

CI2:

BacT (P/A)

☐

Total/E. coli Enum

☐

Other:

CI2:

Relinquished By:

A. Griffiths

Date:

11/6/18

Time:

Received By:

A. Griffiths

Date:

11/6/18

Time:

Received By:

A. Griffiths

Notes/Remarks:

B 183101948

Notice of sample invalidation: samples taken for microbiological determination will be invalidated if: (1) received in the laboratory more than 24 hours after collection, (2) a presence of disinfectant is noticed, (3) evidence of freezing, (4) use of unapproved containers, (5) sample volume < 100 ml, (6) presence of interfering contaminants, (7) sample temperature > 10° C unless collection is within 2 hours of receipt in the laboratory.

Create Coliform CSV File Instructions - Version 8/

1. Enable Macros.
2. Enter sample results starting in the row below the column titles.
3. Press the button.
4. Name the CSV file.
5. Select a folder to save the CSV file to.

Notes:

- OK to change column order, but not column names.
- Only Coliform/E. Coli Results are allowed.

[illegible]