



Certificate of Analysis

Meadow Mt. Water Supply Co.

PO Box 162

CustID# 10757

Allenspark CO

Attn: Andrew Griffiths

Date Received: 12/2/2019

Date Reported: 12/3/2019

Location Name: Meadow Mtn. #3 (RUCH)

Sample Date: 12/2/2019

Sample Time: 9:00:00 AM

Client Sample ID: CO0207504

Matrix: Water

Batch No: 11831



Sample ID: B193361333



Analysis	Results	Units	Limit of Quantitation	Method	Invoice
BacT - Total	Neg	P / A	1 P / A	SM 9223	
BacT-Ecoli	Neg	P / A	1 P / A	SM 9223	
Chlorine, Free	3.2	mg/L	0.08 mg/L	SM 4500-Cl D	

Our Company makes no warranty except that the analysis has been made upon the samples received in accordance with generally accepted testing laboratory principles and practices and by methods approved by the U.S. EPA and State Department of Health. The results of the analysis may not be characteristic of the whole from which the sample was taken.

Results Approved by:

Laboratory/Water Quality Supervisor

Please contact Water Quality Supervisor at 970-577-3624 or via email dcallahan@estes.org if you have any questions regarding the testing above.

Test Note:



ESTES PARK
COLORADO

Town of Estes Park
Water Department
Chain of Custody

Client/Billing Information:

Company: MENARD MTD. WATER SUPPLY CO
Address: BOX 162 AVENUE PARK CO 80510
Contact: ANDREW GRIFFITHS
Phone: (303) 747-2715 e-mail: andrew@esteparkwater.net

System Information:

PWSID# CO0207504
System Address: _____
Contact Person: _____
Phone: _____ e-mail: _____

State Form Information:

State Form Required ☒
Compliance Samples ☒
Submit Forms to State ☒

Yes ☒ No ☐
Yes ☒ No ☐
Yes ☒ No ☐

Water Supply:

Public/Community ☒ Private ☐

Samplers Signature: AT. Griffiths

Sample Location or ID	Date	Time	Analysis:	
<u>Ruck Bleeder #3</u>	<u>12/2/19</u>	<u>9:00a</u>	☒ Total/E. coli Enum	☐ Other: <u>3.2</u>
			☐ BacT (P/A)	☐ Cl2:
			☐ Total/E. coli Enum	☐ Cl2:
			☐ BacT (P/A)	☐ Cl2:
			☐ Total/E. coli Enum	☐ Cl2:
			☐ BacT (P/A)	☐ Cl2:
			☐ Total/E. coli Enum	☐ Cl2:
			☐ BacT (P/A)	☐ Cl2:
			☐ Total/E. coli Enum	☐ Cl2:
			☐ BacT (P/A)	☐ Cl2:
			☐ Total/E. coli Enum	☐ Cl2:
			☐ BacT (P/A)	☐ Cl2:
			☐ Total/E. coli Enum	☐ Cl2:
			☐ BacT (P/A)	☐ Cl2:
			☐ Total/E. coli Enum	☐ Cl2:
			☐ BacT (P/A)	☐ Cl2:

Relinquished By: AG - Griffiths

Date: 12/2/19

Time: 11:00

Received By: Wen Taddario

Relinquished By:

Date:

Time:

Received By:

Notes/Remarks:

B193361333

Create Coliform CSV File Instructions - Version 8/

1. Enable Macros.
2. Enter sample results starting in the row below the column titles.
3. Press the button.
4. Name the CSV file.
5. Select a folder to save the CSV file to.

Notes:

-OK to change column order, but not column names.

-Only Coliform/E. Coli Results are allowed.

[illegible]