



Inorganic Chemicals Certified Laboratory Report Form
WQCD - Drinking Water CAS
Submit Online at <http://www.wqcdcompliance.com/login>

Revised 4/13/2015

IOC

Section I (Supplied or Completed by Public Water System)		Section II (Supplied or Completed by Certified Laboratory)	
Public Water System Information		Certified Laboratory Information	
PWSID#: CO0207504		Laboratory ID: CO 0015	
System Name: Meadow Mtn Water Supply		Laboratory Name: Colorado Analytical Laboratory	
Contact Person: Barry Mauerman	Phone #:	Contact Person: Customer Service	Phone: 303-659-2313
Comments:	Do Samples Need to be Composited BY THE LAB? ☐	Comments:	

Section III (Supplied or Completed by Public Water System)			
Sample Date: 8/1/19	Collector: Barry Mauerman	Facility ID (On Schedule): 001	Sample Pt ID (On Schedule): 001

Section IV Inorganic Chemicals (Completed by Certified Laboratory)								
Lab Receipt Date	Lab Analysis Date	Lab Sample ID	Analyte Name	CAS No.	Analytical Method	MCL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
8/2/19	8/7/19	190802027-01A	Antimony	7740-36-0	EPA 200.8	0.006	0.001	BDL
8/2/19	8/7/19	190802027-01A	Arsenic	7440-38-2	EPA 200.8	0.01	0.001	BDL
8/2/19	8/7/19	190802027-01A	Barium	7440-39-3	EPA 200.8	2	0.001	0.003
8/2/19	8/7/19	190802027-01A	Beryllium	7440-41-7	EPA 200.8	0.004	0.001	BDL
8/2/19	8/7/19	190802027-01A	Cadmium	7440-43-9	EPA 200.8	0.005	0.001	BDL
8/2/19	8/7/19	190802027-01A	Chromium	7440-47-3	EPA 200.8	0.1	0.001	BDL
8/2/19	8/7/19	190802027-01A	Mercury	7439-97-6	EPA 200.8	0.002	0.0001	BDL
8/2/19	8/7/19	190802027-01A	Nickel	7440-02-0	EPA 200.8	N/A	0.001	BDL
8/2/19	8/7/19	190802027-01A	Selenium	7782-49-2	EPA 200.8	0.05	0.001	0.001
8/2/19	8/7/19	190802027-01A	Sodium	7440-23-5	EPA 200.7	N/A	0.1	3.0
8/2/19	8/7/19	190802027-01A	Thallium	7440-28-0	EPA 200.8	0.002	0.001	BDL

NT: Not Tested

Lab MRL: Laboratory Minimum Reporting Level

BDL: Below Laboratory MRL. A less than (<) may also used.

mg/L: Milligrams per Liter

MCL: Maximum Contaminant Level

8/14/19
190802027-01A
1/1
Y

Colorado
Analytical

Report To Information

Commerce City Lab
10411 Heinz Way
Commerce City CO 80640

Lakewood Service Center
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313

www.coloradolab.com

Page 2 of 2
Chlorite