

## Analytical Results

TASK NO: 190627067

**Report To:** Andrew Griffiths

**Company:** Meadow Mountain Water Company  
P.O. Box 162  
Allenspark CO 80510

**Bill To:** Rachel Barkworth

**Company:** Meadow Mountain Water Company  
P.O. Box 162  
Allenspark CO 80510

**Task No.:** 190627067  
**Client PO:**  
**Client Project:** Meadow Mtn Water Supply CO0207504

**Date Received:** 6/27/19  
**Date Reported:** 7/5/19  
**Matrix:** Water - Drinking

**Customer Sample ID** Hans

**Sample Date/Time:** 6/26/19 8:00 AM

**Lab Number:** 190627067-01

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	0.387	EPA 200.8	0.001	6/28/19	1.3
Lead (mg/L)	0.006	EPA 200.8	0.001	6/28/19	0.015

**Abbreviations/ References:**

PQL = Practical Quantification Limit

mg/L = Milligrams Per Liter or PPM

BDL = Below Detectable Levels

Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

## Analytical Results

**TASK NO: 190627067**

**Report To:** Andrew Griffiths

**Company:** Meadow Mountain Water Company  
P.O. Box 162  
Allenspark CO 80510

**Bill To:** Rachel Barkworth

**Company:** Meadow Mountain Water Company  
P.O. Box 162  
Allenspark CO 80510

**Task No.:** 190627067  
**Client PO:**  
**Client Project:** Meadow Mtn Water Supply CO0207504

**Date Received:** 6/27/19  
**Date Reported:** 7/5/19  
**Matrix:** Water - Drinking

**Customer Sample ID** Brock

**Sample Date/Time:** 6/26/19 5:40 AM

**Lab Number:** 190627067-02

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	<b>0.578</b>	EPA 200.8	0.001	6/28/19	1.3
Lead (mg/L)	<b>0.020</b>	EPA 200.8	0.001	6/28/19	0.015

**Abbreviations/ References:**

PQL = Practical Quantification Limit

mg/L = Milligrams Per Liter or PPM

BDL = Below Detectable Levels

Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

## Analytical Results

**TASK NO: 190627067**

**Report To:** Andrew Griffiths

**Company:** Meadow Mountain Water Company  
P.O. Box 162  
Allenspark CO 80510

**Bill To:** Rachel Barkworth

**Company:** Meadow Mountain Water Company  
P.O. Box 162  
Allenspark CO 80510

**Task No.:** 190627067  
**Client PO:**  
**Client Project:** Meadow Mtn Water Supply CO0207504

**Date Received:** 6/27/19  
**Date Reported:** 7/5/19  
**Matrix:** Water - Drinking

**Customer Sample ID** Hames

**Sample Date/Time:** 6/27/19 10:00 AM

**Lab Number:** 190627067-03

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	1.195	EPA 200.8	0.001	6/28/19	1.3
Lead (mg/L)	0.003	EPA 200.8	0.001	6/28/19	0.015

**Abbreviations/ References:**

PQL = Practical Quantification Limit

mg/L = Milligrams Per Liter or PPM

BDL = Below Detectable Levels

Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

## Analytical Results

**TASK NO: 190627067**

**Report To:** Andrew Griffiths

**Company:** Meadow Mountain Water Company  
P.O. Box 162  
Allenspark CO 80510

**Bill To:** Rachel Barkworth

**Company:** Meadow Mountain Water Company  
P.O. Box 162  
Allenspark CO 80510

**Task No.:** 190627067  
**Client PO:**  
**Client Project:** Meadow Mtn Water Supply CO0207504

**Date Received:** 6/27/19  
**Date Reported:** 7/5/19  
**Matrix:** Water - Drinking

**Customer Sample ID** Newton

**Sample Date/Time:** 6/23/19 8:00 AM

**Lab Number:** 190627067-04

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	1.278	EPA 200.8	0.001	6/28/19	1.3
Lead (mg/L)	0.006	EPA 200.8	0.001	6/28/19	0.015

**Abbreviations/ References:**

PQL = Practical Quantification Limit

mg/L = Milligrams Per Liter or PPM

BDL = Below Detectable Levels

Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

## Analytical Results

**TASK NO: 190627067**

**Report To:** Andrew Griffiths

**Company:** Meadow Mountain Water Company  
P.O. Box 162  
Allenspark CO 80510

**Bill To:** Rachel Barkworth

**Company:** Meadow Mountain Water Company  
P.O. Box 162  
Allenspark CO 80510

**Task No.:** 190627067  
**Client PO:**  
**Client Project:** Meadow Mtn Water Supply CO0207504

**Date Received:** 6/27/19  
**Date Reported:** 7/5/19  
**Matrix:** Water - Drinking

**Customer Sample ID** Hill

**Sample Date/Time:** 6/27/19 9:00 AM

**Lab Number:** 190627067-05

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	<b>0.867</b>	EPA 200.8	0.001	6/28/19	1.3
Lead (mg/L)	<b>0.174</b>	EPA 200.8	0.001	6/28/19	0.015

**Abbreviations/ References:**

PQL = Practical Quantification Limit

mg/L = Milligrams Per Liter or PPM

BDL = Below Detectable Levels

Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

## Analytical Results

**TASK NO: 190627067**

**Report To:** Andrew Griffiths

**Company:** Meadow Mountain Water Company  
P.O. Box 162  
Allenspark CO 80510

**Bill To:** Rachel Barkworth

**Company:** Meadow Mountain Water Company  
P.O. Box 162  
Allenspark CO 80510

**Task No.:** 190627067  
**Client PO:**  
**Client Project:** Meadow Mtn Water Supply CO0207504

**Date Received:** 6/27/19  
**Date Reported:** 7/5/19  
**Matrix:** Water - Drinking

**Customer Sample ID** Strom

**Sample Date/Time:** 6/27/19 9:10 AM

**Lab Number:** 190627067-06

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	<b>1.203</b>	EPA 200.8	0.001	6/28/19	1.3
Lead (mg/L)	<b>0.007</b>	EPA 200.8	0.001	6/28/19	0.015

**Abbreviations/ References:**

PQL = Practical Quantification Limit

mg/L = Milligrams Per Liter or PPM

BDL = Below Detectable Levels

Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

# Drinking Water Chain of Custody



LABORATORIES, INC.

**Brighton Lab**  
240 South Main Street  
Brighton, CO 80601

**Lakewood Lab**  
12860 W. Cedar Dr, Suite 100A  
Lakewood CO 80228

Phone: 303-659-2313  
Fax: 303-659-2315

[www.coloradolab.com](http://www.coloradolab.com)

Report To Information		Bill To Information (if different from report to)		State Form / Project Information	
Company Name: <u>MENARD MIN. WATER</u>	Company Name: _____	PWSID: <u>CO 207504</u>			
Contact Name: <u>ANDREW GRIFFITHS</u>	Contact Name: _____	System Name: <u>MENARD MIN. WATER SUPPLY CO.</u>			
Address: <u>Box 162</u>	Address: _____	Address: <u>Box 162</u>			
City: <u>ALDEN</u> State: <u>CO</u> Zip: <u>80510</u>	City: _____ State: _____ Zip: _____	City: <u>ALDEN</u> State: <u>CO</u> Zip: <u>80510</u>			
Phone: <u>(303) 747-2715</u> Fax: _____	Phone: _____ Fax: _____	County: <u>Boulder</u>			
Email: <u>andrewg@menardmin.com</u>	Email: _____	Compliance Samples: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>			
Sampler Name: <u>ANDREW GRIFFITHS</u>	PO No.: _____	Send Forms to State: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>			

CAL Task No. 190627067

JML

CAL Task No. 190627067			PHASE I, II, V Drinking Water Analyses (check analysis)		Subcontract Analyses																									
JML			No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothall	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226	Radium 228	Radon	Uranium	
Date	Time	Client Sample ID / EP Code																												
6/27/19	8:00a	HANS LCR001																												
6/27/19	8:40am	BROCK LCR002																												
6/27/19	10:00a	HANES LCR003																												
6/23/19	8:00a	NEUTON LCR004																												
6/27/19	9:00a	HILL LCR005																												
6/27/19	9:10A	STROM LCR017																												
Instructions:			C/S Info:			Seals Present Yes <input type="checkbox"/> No <input type="checkbox"/> Headspace Yes <input type="checkbox"/> No <input type="checkbox"/>																								

Relinquished By: <u>AD-6/19</u>	Date/Time: <u>6/13/19 1330</u>	Received By: <u>STANNT</u>	Date/Time: <u>6/13/19 1349</u>	Delivered Via: <u>HA</u>	C/S Charge <input type="checkbox"/>	Temp. <u>10</u> °C/ice <u>Y</u>	Sample Pres Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
---------------------------------	--------------------------------	----------------------------	--------------------------------	--------------------------	-------------------------------------	---------------------------------	---