



Lead and Copper Certified Laboratory Report Form
Submit Online: wqcdcompliance.com/login (preferred); Fax (303) 758-1398
WQCD-B2-Drinking Water CAS
4300 Cherry Creek Drive South; Denver, CO 80246-1530

LCR - Results

Revision: 11/01/2016

Section I (Supplied or Completed by Public Water System)				Section II (Supplied or Completed by Certified Laboratory)			
Public Water System Information				Certified Laboratory Information			
PWSID#: CO0207504		Facility ID: DS001		Laboratory ID: CO 0015			
System Name: Meadow Mtn Water Supply				Laboratory Name: Colorado Analytical Laboratory			
Contact Person: Barry Mauerman		Phone #: 303-747-2066		Contact Person: Customer Service		Phone: 303-659-2313	
Comments:				Comments:			

Section III (Supplied or Completed by Public Water System)				Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Collector	Sample Pt ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
11/17/19		LCR001	Hans	11/18/19	11/25/19	191118036-01	Copper	EPA 200.8	1.3	0.001	0.311
							Lead	EPA 200.8	0.015	0.001	0.004
Sample Date	Collector	Sample Pt ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
11/18/19		LCR002	Brock	11/18/19	11/25/19	191118036-02	Copper	EPA 200.8	1.3	0.001	0.483
							Lead	EPA 200.8	0.015	0.001	0.003
Sample Date	Collector	Sample Pt ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
11/17/19		LCR004	Newton	11/18/19	11/25/19	191118036-03	Copper	EPA 200.8	1.3	0.001	0.534
							Lead	EPA 200.8	0.015	0.001	0.001
Sample Date	Collector	Sample Pt ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
11/18/19		LCR005	Hill	11/18/19	11/25/19	191118036-04	Copper	EPA 200.8	1.3	0.001	0.517
							Lead	EPA 200.8	0.015	0.001	0.065
Sample Date	Collector	Sample Pt ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
11/17/19		LCR017	Strom	11/18/19	11/25/19	191118036-05	Copper	EPA 200.8	1.3	0.001	0.517
							Lead	EPA 200.8	0.015	0.001	0.002

NT: Not Tested
 Lab MRL: Laboratory Minimum Reporting Level
 BDL: Below Laboratory MRL. A less than (<) may also used.

mg/L: Milligrams per Liter
 AL: Action Level

191118036 Y

1/1

Colorado
Analytical

Colorado
Analytical

Commerce City Lab
10411 Heinz Way
Commerce City CO 80640

Lakewood Service Center
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313

www.coloradolab.com

Page 2 of 2