



Lead and Copper Certified Laboratory Report Form
Submit Online: wqcdcompliance.com/login (preferred); Fax (303) 758-1398
WQCD-B2-Drinking Water CAS
4300 Cherry Creek Drive South; Denver, CO 80246-1530

LCR - Results

Revision: 11/01/2016

Section I (Supplied or Completed by Public Water System)				Section II (Supplied or Completed by Certified Laboratory)							
Public Water System Information				Certified Laboratory Information							
PWSID#: CO0207504		Facility ID: DS001		Laboratory ID: CO 0015							
System Name: Meadow Mtn Water Supply				Laboratory Name: Colorado Analytical Laboratory							
Contact Person: Barry Mauerman			Phone #: 303-747-2066	Contact Person: Customer Service				Phone: 303-659-2313			
Comments:				Comments:							

Section III (Supplied or Completed by Public Water System)				Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Collector	Sample Pt ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
12/7/19	Barry Mauerm	LCR003	Hames	12/10/19	12/12/19	191210059-01	Copper	EPA 200.8	1.3	0.001	0.122
							Lead	EPA 200.8	0.015	0.001	0.002

NT: Not Tested
Lab MRL: Laboratory Minimum Reporting Level
BDL: Below Laboratory MRL. A less than (<) may also used.

mg/L: Milligrams per Liter
AL: Action Level

191210059 Y

1/1

Colorado
Analytical



Colorado
Analytical
LABORATORIES, INC.

Commerce City Lab
10411 Heinz Way
Commerce City CO 80640

Lakewood Service Center
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313

www.coloradolab.com

Page 2 of 2