

Analytical Results

TASK NO: 191213014

Report To: Barry Mauerman

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Rachel Barkworth

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 191213014
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 12/13/19
Date Reported: 12/19/19
Matrix: Water - Drinking

Customer Sample ID Distribution - Entry

Sample Date/Time: 12/11/19 9:15 AM

Lab Number: 191213014-01

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	0.006	EPA 200.8	0.001	12/16/19	1.3
Lead (mg/L)	BDL	EPA 200.8	0.001	12/16/19	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit

mg/L = Milligrams Per Liter or PPM

BDL = Below Detectable Levels

Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Analytical Results

TASK NO: 191213014

Report To: Barry Mauerman

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Rachel Barkworth

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 191213014
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 12/13/19
Date Reported: 12/19/19
Matrix: Water - Drinking

Customer Sample ID Distribution - Mauerman

Sample Date/Time: 12/11/19 10:30 AM

Lab Number: 191213014-02

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	0.072	EPA 200.8	0.001	12/16/19	1.3
Lead (mg/L)	BDL	EPA 200.8	0.001	12/16/19	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit

mg/L = Milligrams Per Liter or PPM

BDL = Below Detectable Levels

Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Drinking Water Chain of Custody



LABORATORIES, INC.

Commerce City Lab
10411 Heinz Way
Commerce City CO 80640

Lakewood Service Center
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313

www.coloradolab.com

Report To Information		Bill To Information (if different from report to)		Project Information	
Company Name: <u>MEADOWS MOUSSE</u>	Company Name: _____	Company Name: _____	PWSID: <u>0207504</u>	System Name: <u>MEADOWS MOUSSE</u>	
Contact Name: <u>BARRY MAUERKMAN</u>	Contact Name: _____	Contact Name: _____	Compliance Samples: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Send Results to CDPHE: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
Address: <u>P.O. Box 162</u>	Address: _____	Address: _____	Task Number (Lab Use Only)	CAL Task No. <u>191213014</u>	
City/State/Zip: <u>CO zip: 80500</u>	City: _____ State: _____ Zip: _____	City: _____ State: _____ Zip: _____	Phone: <u>303-747-0317</u>	Email: _____	
Phone: <u>303-747-0317</u>	Phone: _____	Phone: _____	Sample Collector: <u>BARRY MAUERKMAN</u>	Sample Collector Phone: <u>303-747-0317</u>	
Email: <u>barry.mauerkmn@gmail.com</u>	Email: _____	Email: _____	PO Number: _____	PO Number: _____	

				PHASE I, II, V Drinking Water Analyses (check requested analysis)														Subcontract Analyses												
Date	Time	Client Sample ID / Sample Pt ID	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothall	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index (Circle)	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226/228	Radon	Uranium	Chlorine	
12/11/11	0915	DKR180700-ENVTRY	1															X												
12/11/11	1030	DKR180700-MAUERKMAN	1															X												
12/11/11	0915	DKR180700-ENVTRY	4																											
12/11/11	1030	DKR180700-MAUERKMAN	4																											
12/12/11	1000	DKR180700-ENVTRY	4																											
12/12/11	1230	DKR180700-MAUERKMAN	4																											

Instructions: Barry OK to run out of holding tank (aka-P) - H

Relinquished By: Barry Mauerkmn Date/Time: 12/13/11 10:54 Received By: J. K. Date/Time: 12/13/11 10:54

Seals Present Yes ☐ No ☐ Headspace Yes ☐ No ☐

Temp. 31 °C / Ice Y Sample Pres. Yes ☒ No ☐

JML

- Alkalinity
- Calcium (as mg/L CaCO_3)
- Total Dissolved Solids
- ~~Silica (only if an inhibitor containing silica is used)~~
- Orthophosphate (mg/L as P)* (required even if an inhibitor containing phosphate is not used)
- Total phosphorus (mg/L as P)
- Chloride
- Sulfate
- Iron
- Manganese

* Note, if an orthophosphate concentration is given in units of "mg/L as PO_4 " or "mg/L as orthophosphate," the value must be divided by 3 to convert to "mg/L as P"