

Analytical Results

TASK NO: 190627067

Report To: Andrew Griffiths

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Rachel Barkworth

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 190627067
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 6/27/19
Date Reported: 7/5/19
Matrix: Water - Drinking

Customer Sample ID Hames

Sample Date/Time: 6/27/19 10:00 AM

Lab Number: 190627067-03

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	1.195	EPA 200.8	0.001	6/28/19	1.3
Lead (mg/L)	0.003	EPA 200.8	0.001	6/28/19	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit

mg/L = Milligrams Per Liter or PPM

BDL = Below Detectable Levels

Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY