

## Analytical Results

**TASK NO: 190627067**

**Report To:** Andrew Griffiths

**Company:** Meadow Mountain Water Company  
P.O. Box 162  
Allenspark CO 80510

**Bill To:** Rachel Barkworth

**Company:** Meadow Mountain Water Company  
P.O. Box 162  
Allenspark CO 80510

**Task No.:** 190627067  
**Client PO:**  
**Client Project:** Meadow Mtn Water Supply CO0207504

**Date Received:** 6/27/19  
**Date Reported:** 7/5/19  
**Matrix:** Water - Drinking

**Customer Sample ID** Hans

**Sample Date/Time:** 6/26/19 8:00 AM

**Lab Number:** 190627067-01

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	0.387	EPA 200.8	0.001	6/28/19	1.3
Lead (mg/L)	0.006	EPA 200.8	0.001	6/28/19	0.015

**Abbreviations/ References:**

PQL = Practical Quantification Limit

mg/L = Milligrams Per Liter or PPM

BDL = Below Detectable Levels

Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY