



Colorado Department
of Public Health
and Environment

Nitrate and Nitrite as Nitrogen Certified Laboratory Report Form
WQCD - Drinking Water CAS
Submit Online at <http://www.wqcdcompliance.com/login>

Revised 4/13/2015

NOX

Section I (Supplied or Completed by Public Water System)					Section II (Supplied or Completed by Certified Laboratory)							
Public Water System Information					Certified Laboratory Information							
PWSID#: CO0207504					Laboratory ID: CO 0015							
System Name: Meadow Mtn Water Supply					Laboratory Name: Colorado Analytical Laboratory							
Contact Person: Barry Mauerman			Phone #: 303-747-2066		Contact Person: Customer Service				Phone: 303-659-2313			
Comments:					Comments:							

Section III (Supplied or Completed by Public Water System)					Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Collector	Facility ID On Schedule	Sample Pt ID On Schedule	Confirmation?	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	MCL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
8/1/19	Barry Mauerman	001	001	☐	8/2/19	8/2/19	190802027-01	Nitrate Nitrogen	EPA 300.0	10	0.1	BDL
8/1/19	Barry Mauerman	001	001	☐	8/2/19	8/2/19	190802027-01	Nitrite Nitrogen	EPA 300.0	1	0.1	BDL

NT: Not Tested
 Lab MRL: Laboratory Minimum Reporting Level
 BDL: Below Laboratory MRL. A less than (<) may also used.

mg/L: Milligrams per Liter
 MCL: Maximum Contaminant Level

8/14/19
 190802027-01
 1/ 1
 Y

Colorado
Analytical

Project Information

Commerce City Lab
10411 Heinz Way
Commerce City CO 80640

Lakewood Service Center
12860 W. Cedar Dr., Suite 100A
Lakewood CO 80228

Phone: 303-659-2313

www.coloradolab.com

Page 2 of 2