



Colorado Department
of Public Health
and Environment

Total Trihalomethane Certified Laboratory Report Form
WQCD - Drinking Water CAS
Submit Online at <http://www.wqcdcompliance.com/login>

Revision: 4/13/2015

TTHM

Section I (to be completed by the Public Water Systems only)						Section II (to be completed by Laboratories only)				
Public Water System Information						Laboratory Information				
PWSID#: CO0207504			Facility ID:DBP001			Laboratory ID: CO 0015				
System Name: Meadow Mtn Water Supply						Laboratory Name: Colorado Analytical Laboratory				
Contact Person: Barry Mauerman			Phone #: 303-747-2066			Contact Person: Customer Service		Phone: 303-659-2313		
Comments:						Comments:				
Section III (Supplied or Completed by PWS)			Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Sample Pt ID On Schedule	Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	MCL (ug/L)	Lab MRL (ug/L)	Result (ug/L)
8/1/19	DBP001	Triple Creek Ranch Dale Drive	8/2/19	8/8/19	190802027-02A	Chloroform	EPA-524.2	N/A	0.5	23.5
						Bromoform	EPA-524.2	N/A	0.5	BDL
						Bromodichloromethane	EPA-524.2	N/A	0.5	1.4
						Dibromochloromethane	EPA-524.2	N/A	0.5	BDL
						Total Trihalomethanes	EPA-524.2	80	0.5	24.9

NT: Not Tested

Lab MRL: Laboratory Minimum Reporting Level

BDL: Below Laboratory MRL. A less than (<) may also used.

ug/L: Micrograms per Liter

MCL: Maximum Contaminant Level

8/14/19

190802027

1/1

Y

Colorado
Analytical

Report To Information

Commerce City Lab
10411 Heinz Way
Commerce City CO 80640

Lakewood Service Center
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313

www.coloradolab.com

Page 2 of 2