

Analytical Results

TASK NO: 200507054

Report To: Barry Mauerman

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Rachel Barkworth

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 200507054
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 5/7/20
Date Reported: 5/14/20
Matrix: Water - Drinking

Customer Sample ID Brock

Sample Date/Time: 5/6/20 7:00 AM

Lab Number: 200507054-01

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	0.741	EPA 200.8	0.001	5/8/20	1.3
Lead (mg/L)	0.013	EPA 200.8	0.001	5/8/20	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit
mg/L = Milligrams Per Liter or PPM
BDL = Below Detectable Levels
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Analytical Results

TASK NO: 200507054

Report To: Barry Mauerman

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Rachel Barkworth

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 200507054
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 5/7/20
Date Reported: 5/14/20
Matrix: Water - Drinking

Customer Sample ID Newton

Sample Date/Time: 5/6/20 7:00 AM

Lab Number: 200507054-02

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	1.178	EPA 200.8	0.001	5/8/20	1.3
Lead (mg/L)	0.006	EPA 200.8	0.001	5/8/20	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit
mg/L = Milligrams Per Liter or PPM
BDL = Below Detectable Levels
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Analytical Results

TASK NO: 200507054

Report To: Barry Mauerman

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Rachel Barkworth

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 200507054
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 5/7/20
Date Reported: 5/14/20
Matrix: Water - Drinking

Customer Sample ID Hill

Sample Date/Time: 5/6/20 7:00 AM

Lab Number: 200507054-03

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	1.501	EPA 200.8	0.001	5/8/20	1.3
Lead (mg/L)	0.070	EPA 200.8	0.001	5/8/20	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit
mg/L = Milligrams Per Liter or PPM
BDL = Below Detectable Levels
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Analytical Results

TASK NO: 200507054

Report To: Barry Mauerman

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Rachel Barkworth

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 200507054
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 5/7/20
Date Reported: 5/14/20
Matrix: Water - Drinking

Customer Sample ID Strom

Sample Date/Time: 5/6/20 7:00 AM

Lab Number: 200507054-04

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	0.778	EPA 200.8	0.001	5/8/20	1.3
Lead (mg/L)	0.005	EPA 200.8	0.001	5/8/20	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit
mg/L = Milligrams Per Liter or PPM
BDL = Below Detectable Levels
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Report To Information		Bill To Information (If different from report to)		State Form / Project Information	
Company Name:	NEARCO MECHANICAL WATER SUPPLY CO.	Company Name:		PWSID:	CO 207504
Contact Name:	ANDREW GRIFATHIS	Contact Name:		System Name:	NEARCO MECHANICAL WATER SUPPLY
Address:	P.O. Box 162	Address:		Address:	PO Box 162
City/ALLEN PARK State Co zip 80510		City	State Zip	City/ALLEN PARK State Co zip 80510	
Phone: (303) 747-2715 Fax:		Phone:	Fax:	County:	Boulder
Email: andy@nearco.net		Email:		Compliance Samples: Yes ☒ No ☐	
Sampler Name: ANDREW GRIFATHIS		PO No.:		Send Forms to State: Yes ☒ No ☐	

Lakewood Lab
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

www.coloradolab.com

[illegible]

13:20