

Analytical Results

TASK NO: 201123066

Report To: Barry Mauerman

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Rachel Barkworth

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 201123066
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 11/23/20
Date Reported: 11/30/20
Matrix: Water - Drinking

Customer Sample ID Newton

Sample Date/Time: 11/23/20 7:30 AM

Lab Number: 201123066-01

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	0.183	EPA 200.8	0.001	11/24/20	1.3
Lead (mg/L)	BDL	EPA 200.8	0.001	11/24/20	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit
mg/L = Milligrams Per Liter or PPM
BDL = Below Detectable Levels
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Analytical Results

TASK NO: 201123066

Report To: Barry Mauerman

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Rachel Barkworth

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 201123066
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 11/23/20
Date Reported: 11/30/20
Matrix: Water - Drinking

Customer Sample ID Hans

Sample Date/Time: 11/23/20 7:30 AM

Lab Number: 201123066-02

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	0.135	EPA 200.8	0.001	11/24/20	1.3
Lead (mg/L)	0.003	EPA 200.8	0.001	11/24/20	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit
mg/L = Milligrams Per Liter or PPM
BDL = Below Detectable Levels
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Analytical Results

TASK NO: 201123066

Report To: Barry Mauerman

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Rachel Barkworth

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 201123066
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 11/23/20
Date Reported: 11/30/20
Matrix: Water - Drinking

Customer Sample ID Brock

Sample Date/Time: 11/23/20 7:30 AM

Lab Number: 201123066-03

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	0.192	EPA 200.8	0.001	11/24/20	1.3
Lead (mg/L)	0.003	EPA 200.8	0.001	11/24/20	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit
mg/L = Milligrams Per Liter or PPM
BDL = Below Detectable Levels
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Colorado
Analytical
LABORATORIES, INC.

Commerce City Lab
10411 Heinz Way
Commerce City CO 80640

Lakewood Service Center
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313

www.coloradolab.com

Page 4 of 4