

Analytical Results

TASK NO: 200507054

Report To: Barry Mauerman

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Rachel Barkworth

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 200507054
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 5/7/20
Date Reported: 5/14/20
Matrix: Water - Drinking

Customer Sample ID Brock

Sample Date/Time: 5/6/20 7:00 AM

Lab Number: 200507054-01

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	0.741	EPA 200.8	0.001	5/8/20	1.3
Lead (mg/L)	0.013	EPA 200.8	0.001	5/8/20	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit
mg/L = Milligrams Per Liter or PPM
BDL = Below Detectable Levels
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Analytical Results

TASK NO: 200507054

Report To: Barry Mauerman

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Rachel Barkworth

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 200507054
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 5/7/20
Date Reported: 5/14/20
Matrix: Water - Drinking

Customer Sample ID Newton

Sample Date/Time: 5/6/20 7:00 AM

Lab Number: 200507054-02

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	1.178	EPA 200.8	0.001	5/8/20	1.3
Lead (mg/L)	0.006	EPA 200.8	0.001	5/8/20	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit
mg/L = Milligrams Per Liter or PPM
BDL = Below Detectable Levels
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Analytical Results

TASK NO: 200507054

Report To: Barry Mauerman

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Rachel Barkworth

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 200507054
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 5/7/20
Date Reported: 5/14/20
Matrix: Water - Drinking

Customer Sample ID Hill

Sample Date/Time: 5/6/20 7:00 AM

Lab Number: 200507054-03

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	1.501	EPA 200.8	0.001	5/8/20	1.3
Lead (mg/L)	0.070	EPA 200.8	0.001	5/8/20	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit
mg/L = Milligrams Per Liter or PPM
BDL = Below Detectable Levels
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Analytical Results

TASK NO: 200507054

Report To: Barry Mauerman

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Rachel Barkworth

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 200507054
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 5/7/20
Date Reported: 5/14/20
Matrix: Water - Drinking

Customer Sample ID Strom

Sample Date/Time: 5/6/20 7:00 AM

Lab Number: 200507054-04

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	0.778	EPA 200.8	0.001	5/8/20	1.3
Lead (mg/L)	0.005	EPA 200.8	0.001	5/8/20	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit

mg/L = Milligrams Per Liter or PPM

BDL = Below Detectable Levels

Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Drinking Water Chain of Custody



LABORATORIES, INC.

Brighton Lab
240 South Main Street
Brighton, CO 80601

Lakewood Lab
12860 W. Cedar Dr., Suite 100A
Lakewood CO 80228

Phone: 303-659-2313
Fax: 303-659-2315

www.coloradolab.com

Report To Information		Bill To Information (if different from report to)		State Form / Project Information	
Company Name: <u>MEADOW HUNTING WATER SUPPLY CO.</u>		Company Name: _____		PWSID: <u>CO 707504</u>	
Contact Name: <u>ANDREW GRIFFITHS</u>		Contact Name: _____		System Name: <u>MEADOW HUNTING WATER SUPPLY CO.</u>	
Address: <u>P.O. Box 162</u>		Address: _____		Address: <u>PO Box 162</u>	
City: <u>ALLEN PARK State CO</u>		City: _____		City: <u>ALLEN PARK State CO</u>	
Zip: <u>80510</u>		Zip: _____		Zip: <u>80510</u>	
Phone: <u>303 747-2715</u>		Phone: _____		County: <u>Boulder</u>	
Fax: _____		Fax: _____		Compliance Samples: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
Email: <u>andrews@earthlink.net</u>		Email: _____		Send Forms to State: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
Sampler Name: <u>ANDREW GRIFFITHS</u>		PO No.: _____			

PHASE I, II, V Drinking Water Analyses (check analysis)

Subcontract Analyses

Date	Time	Client Sample ID / EP Code	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothall	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226	Radium 228	Radon	Uranium
5/6/00	7:00a	44445 <u>44445</u>	1																										
		<u>BROCK LCR002</u>	1																										
		<u>NEUTON LCR004</u>	1																										
		<u>HILL LCR005</u>	1																										
		<u>STROM LCR017</u>	1																										

Instructions: _____

C/S Info: _____

Seals Present Yes ☐ No ☐ Headspace Yes ☐ No ☐

Relinquished By: _____	Date/Time: _____	Received By: <u>gjk</u>	Date/Time: <u>5/7/00</u>	Delivered Via: <u>Hand</u>	C/S Charge <input type="checkbox"/>	Date/Time: _____	Temp. <u>108</u> °C/lcc <u>Y</u>	Sample Pres. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	Date/Time: _____
------------------------	------------------	-------------------------	--------------------------	----------------------------	-------------------------------------	------------------	----------------------------------	--	------------------