

Analytical Results

TASK NO: 200608059

Report To: Andrew Griffiths

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Andrew Griffiths

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 200608059
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 6/8/20
Date Reported: 6/17/20
Matrix: Water - Drinking

Customer Sample ID HAMES

Sample Date/Time: 6/5/20 8:00 AM

Lab Number: 200608059-04

| Test | Result | Method | PQL | Date Analyzed | MCL |
|---------------|--------|-----------|-------|---------------|-------|
| <i>Total</i> | | | | | |
| Copper (mg/L) | 1.280 | EPA 200.8 | 0.001 | 6/9/20 | 1.3 |
| Lead (mg/L) | 0.005 | EPA 200.8 | 0.001 | 6/9/20 | 0.015 |

Abbreviations/ References:

PQL = Practical Quantification Limit

mg/L = Milligrams Per Liter or PPM

BDL = Below Detectable Levels

Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY