

Analytical Results

TASK NO: 201123066

Report To: Barry Mauerman

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Rachel Barkworth

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 201123066

Client PO:

Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 11/23/20

Date Reported: 11/30/20

Matrix: Water - Drinking

Customer Sample ID Newton

Sample Date/Time: 11/23/20 7:30 AM

Lab Number: 201123066-01

Test	Result	Method	PQL	Date Analyzed	MCL
<u>Total</u>					
Copper (mg/L)	0.183	EPA 200.8	0.001	11/24/20	1.3
Lead (mg/L)	BDL	EPA 200.8	0.001	11/24/20	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit

mg/L = Milligrams Per Liter or PPM

BDL = Below Detectable Levels

Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

10411 Heinz Way / Commerce City, CO 80640 / 303-659-2313
Mailing Address: P.O. Box 507 / Brighton, CO 80601-0507