

## Analytical Results

**TASK NO: 200507055**

**Report To:** Barry Mauerman

**Company:** Meadow Mountain Water Company  
P.O. Box 162  
Allenspark CO 80510

**Bill To:** Rachel Barkworth

**Company:** Meadow Mountain Water Company  
P.O. Box 162  
Allenspark CO 80510

**Task No.:** 200507055  
**Client PO:**  
**Client Project:** Meadow Mtn Water Supply CO0207504

**Date Received:** 5/7/20  
**Date Reported:** 5/14/20  
**Matrix:** Water - Drinking

**Customer Sample ID** Ross

**Sample Date/Time:** 5/6/20 7:00 AM

**Lab Number:** 200507055-02

| Test          | Result | Method    | PQL   | Date Analyzed | MCL   |
|---------------|--------|-----------|-------|---------------|-------|
| <i>Total</i>  |        |           |       |               |       |
| Copper (mg/L) | 0.085  | EPA 200.8 | 0.001 | 5/8/20        | 1.3   |
| Lead (mg/L)   | 0.002  | EPA 200.8 | 0.001 | 5/8/20        | 0.015 |

**Abbreviations/ References:**

PQL = Practical Quantification Limit

mg/L = Milligrams Per Liter or PPM

BDL = Below Detectable Levels

Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY