

Analytical Results

TASK NO: 200507054

Report To: Barry Mauerman

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Rachel Barkworth

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 200507054
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 5/7/20
Date Reported: 5/14/20
Matrix: Water - Drinking

Customer Sample ID Strom

Sample Date/Time: 5/6/20 7:00 AM

Lab Number: 200507054-04

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	0.778	EPA 200.8	0.001	5/8/20	1.3
Lead (mg/L)	0.005	EPA 200.8	0.001	5/8/20	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit
mg/L = Milligrams Per Liter or PPM
BDL = Below Detectable Levels
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY