

Analytical Results

TASK NO: 201211036

Report To: Barry Mauerman

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Rachel Barkworth

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 201211036
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 12/11/20
Date Reported: 12/18/20
Matrix: Water - Drinking

Customer Sample ID Strom

Sample Date/Time: 12/9/20 9:00 AM

Lab Number: 201211036-02

Test	Result	Method	PQL	Date Analyzed	MCL
<u>Total</u>					
Copper (mg/L)	0.154	EPA 200.8	0.001	12/14/20	1.3
Lead (mg/L)	BDL	EPA 200.8	0.001	12/14/20	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit
mg/L = Milligrams Per Liter or PPM
BDL = Below Detectable Levels
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

10411 Heinz Way / Commerce City, CO 80640 / 303-659-2313
Mailing Address: P.O. Box 507 / Brighton, CO 80601-0507