

Analytical Results

TASK NO: 200608059

Report To: Andrew Griffiths

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Andrew Griffiths

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 200608059
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 6/8/20
Date Reported: 6/17/20
Matrix: Water - Drinking

Customer Sample ID HANS

Sample Date/Time: 6/6/20 8:00 AM

Lab Number: 200608059-03

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	0.598	EPA 200.8	0.001	6/9/20	1.3
Lead (mg/L)	0.007	EPA 200.8	0.001	6/9/20	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit

mg/L = Milligrams Per Liter or PPM

BDL = Below Detectable Levels

Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Analytical Results

TASK NO: 200608059

Report To: Andrew Griffiths

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Andrew Griffiths

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 200608059
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 6/8/20
Date Reported: 6/17/20
Matrix: Water - Drinking

Customer Sample ID HAMES

Sample Date/Time: 6/5/20 8:00 AM

Lab Number: 200608059-04

Test	Result	Method	PQL	Date Analyzed	MCL
<i>Total</i>					
Copper (mg/L)	1.280	EPA 200.8	0.001	6/9/20	1.3
Lead (mg/L)	0.005	EPA 200.8	0.001	6/9/20	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit

mg/L = Milligrams Per Liter or PPM

BDL = Below Detectable Levels

Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

Drinking Water Chain of Custody



LABORATORIES, INC.

Brighton Lab
240 South Main Street
Brighton, CO 80601

Lakewood Lab
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313
Fax: 303-659-2315

www.coloradolab.com

Report to Information		Bill To Information (if different from report to)		State Form / Project Information	
Company Name: <u>MEADCO Wm. WARR SUPPLY CO.</u>	Company Name: _____	PWSID: <u>CO 707504</u>			
Contact Name: <u>ANDREW COPELAND</u>	Contact Name: _____	System Name: <u>MEADCO Wm. WARR SUPPLY CO.</u>			
Address: <u>Box 162</u>	Address: _____	Address: <u>Box 162</u>			
City: <u>ALDEN</u>	City: _____	City: <u>ALDEN</u>	State: <u>CO</u>	Zip: <u>80510</u>	
Phone: <u>303-747-2715</u>	Phone: _____	County: <u>BOULDER</u>			
Fax: _____	Fax: _____	Compliance Samples: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>			
Email: <u>andrew@meadco.com</u>	Email: _____	Send Forms to State: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>			
Sample Name: <u>ANDREW COPELAND</u>	PO No.: _____				

PHASE I, II, V Drinking Water Analyses (check analysis)

Subcontract Analyses

Date	Time	Client Sample ID / EP Code	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothall	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226	Radium 228	Radon	Uranium
6/6/20	10:00	NITRATE EP001	1															X	X	X									
		INORGANICS	1																										
		PCB/UV 226+228	3																										
		COMBINED INORGANIC	1																										
		GROSS ALPHA	1																										
6/6/20	8:00	HANS LCR001	1														X												
6/5/20	8:00	HANES LCR003	1														X												

Instructions:

Sample Pt 113 + EP code taken from mon. schedule

C/S Info:

Seals Present Yes ☐ No ☒ Headspace Yes ☐ No ☒

Relinquished By:

6/6/20 1:48

Received By:

6/8/20 1:48

Date/Time:

Relinquished Via:

C/S Change ☐

Temp. 7

Received By:

Sample Pres Yes ☒ No ☐

Date/Time: