

DAY	TIME	CERT	Raw			Finished		Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser
			NTU	pH	temp	NTU	CLR	CLR	pH	In	Out														
	24 Hr	Initials			deg C	<.1	mg/L	>1.2mg/L		PSI	PSI	Baseline TMP was 10 psi										X	P/F	gpm	Gpd
1	1010	Bm	0.29	6.9	2.5	.025	1.5	1.5	7.0	52	51	9	10	9	10	10	10	10	10	10			24.4	3235827	
2	0925	Bm	0.49	7.0	2.0	.025	1.5	1.4	7.1	52	51	10	10	10	10	10	10	11	11	10			24.3	3237915	
3	0955	TW	0.27	6.8	2.0	.025	1.5	1.3	7.0	52	51	10	9	9	9	9	9	9	10	9			24.9	3239899	
4	0955	TW	0.26	6.8	2.0	.025	1.6	1.5	7.0	52	51	11	10	10	10	12	10	10	10	11			24.7	3241774	
5	0830	Bm	0.30	6.9	2.5	.025	1.7	1.6	7.0	52	51	10	11	10	10	10	10	11	10	10			25.0	3243580	
6	1020	Bm	0.49	6.8	2.5	.025	1.5	1.3	7.0	52	51	10	10	10	10	11	10	10	11	10			24.9	3245607	
7	1055	Bm	0.35	6.8	2.5	.025	1.4	1.4	7.0	52	51	10	11	10	10	10	10	11	11	10	X		24.2	3247476	
8	0740	Bm	0.52	6.8	2.0	.025	1.4	1.4	7.0	63	61	15	14	14	14	15	14	15	15	16	15			40.9	3249477
9	1130	Bm	0.48	6.9	2.0	.025	1.5	1.4	7.0	63	61	15	15	15	15	16	16	15	15	16	15			42.0	3252291
10	1050	TW	0.28	6.8	2.0	.026	1.5	1.3	6.9	63	61	15	15	15	15	16	17	15	16	17	17			43.5	3254639
11	1015	TW	0.29	6.8	2.0	.026	1.6	1.4	6.9	63	62	17	15	15	15	15	17	15	16	18	17			43.0	3257079
12	0845	Bm	0.43	6.8	2.0	.026	1.4	1.4	6.9	63	61	15	16	15	15	16	15	16	16	17	16			42.7	3259449
13	740	Bm	0.51	6.8	2.0	.027	1.5	1.3	6.9	63	61	16	15	15	15	15	15	15	15	17	16			42.1	3261889
14	0905	Bm	0.36	6.9	2.0	.027	1.6	1.4	7.0	63	61	16	15	15	15	16	16	16	16	17	16	X	X	42.1	3264469
15	0850	Bm	0.45	6.9	2.0	.025	1.6	1.5	7.0	63	61	15	15	14	15	15	15	16	16	17	16			40.1	3266864
16	1010	Bm	0.49	6.9	2.0	.025	1.5	1.5	7.0	63	61	15	15	15	15	16	15	15	15	16	15			42.0	3269466
17	1300	TW	0.29	6.8	2.0	.025	1.5	1.3	6.9	63	61	17	14	14	14	16	14	15	15	16	16			42.0	3272227
18	0935	TW	0.27	6.8	1.5	.025	1.5	1.2	6.9	63	61	18	14	16	14	16	15	14	15	17	16			42.0	3274353
19	0950	Bm	0.33	6.8	2.0	.025	1.4	1.3	6.9	63	61	15	15	15	15	16	16	15	17	16			41.6	3276914	
20	0820	Bm	0.48	6.8	2.0	.025	1.7	1.4	7.0	63	61	15	15	14	15	15	15	15	16	16	15			41.2	3279296
21	0720	Bm	0.37	6.8	2.0	.025	1.5	1.4	7.0	63	60	14	15	14	14	15	15	14	14	16	15	X		41.2	3281662
22	0915	Bm	0.26	6.8	2.15	.025	1.4	1.4	7.0	64	60	15	14	14	14	15	15	15	15	16	15			40.0	3284316
23	0850	Bm	0.32	6.9	2.0	.025	1.5	1.4	7.0	62	61	16	15	15	16	16	16	16	15	16	16			42.6	3286692
24	1110	TW	0.36	6.8	2.0	.025	1.7	1.3	6.9	63	61	17	14	14	15	16	17	15	15	17	15			42.5	3289372
25	0920	TW	0.29	6.8	2.0	.025	1.6	1.4	7.0	63	61	18	14	14	14	16	15	16	15	17	16			42.3	3291617
26	0940	Bm	0.35	6.8	2.0	.025	1.6	1.4	7.0	63	61	15	16	15	14	15	15	15	15	16	16			42.1	3294105
27	0810	Bm	0.43	6.8	2.0	.025	1.7	1.5	7.0	63	61	16	15	15	14	16	15	16	15	17	16			42.1	3296407
28	0845	Bm	0.48	6.8	2.0	.025	1.6	1.4	7.0	63	61	16	15	16	15	15	15	15	15	16	16	X		41.8	3298919
29	0850	Bm	0.29	6.8	2.0	.025	1.7	1.5	7.0	63	61	16	15	15	15	16	16	15	15	17	16			42.2	3301340
30	0905	Bm	0.35	6.7	2.0	.025	1.7	1.6	7.0	63	61	16	15	15	16	16	15	15	16	17	16			41.9	3303810
31	0930	TW	0.30	6.8	1.5	.025	1.5	1.4	6.9	63	61	18	15	15	16	17	16	16	16	17	16			41.7	3306315
BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.																									
Change Bag Filters as needed to provide adequate pressure to membrnaes.																									

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

Change Bag Filters as needed to provide adequate pressure to membranes.

[illegible]