

DAY	TIME	CERT	Raw			Finished		Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser
			NTU	pH	temp	NTU	CLR	CLR	pH	In	Out	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	gpm	Gpd
			24 Hr	Initials	deg C	<1	mg/L	>1.2mg/L		PSI	PSI	Baseline TMP was 10 psi													
1	0945	TW	0.31	6.8	1.5	0.25	1.5	1.5	6.9	63	61	18	14	14	14	16	16	16	15	17	17			41.1	3308886
2	0840	TW	0.28	6.8	2.0	0.25	1.6	1.5	7.0	63	61	17	15	16	15	17	16	17	16	18	16			41.2	3311319
3	0850	TW	0.29	6.8	2.0	0.26	1.7	1.5	7.0	63	61	18	15	15	15	16	17	16	15	17	18			41.3	3313739
4	1140	TW	0.36	6.8	1.5	0.24	1.5	1.4	6.9	63	61	19	15	16	16	17	16	17	16	18	16			41.7	3316562
5	1000	TW	0.29	6.8	1.5	0.25	1.5	1.4	6.9	63	61	18	15	15	15	16	16	16	16	17	16	X		40.8	3318752
6	1030	TW	0.34	6.8	1.5	0.29	1.5	1.4	7.0	63	61	19	15	14	14	16	15	16	16	18	17			40.8	3322150
7	0922	TW	0.29	6.8	1.5	0.26	1.5	1.5	6.9	64	61	18	14	16	15	17	16	16	16	17	17			40.5	3323528
8	0940	TW	0.29	6.8	1.5	0.25	1.6	1.4	6.9	63	62	17	16	16	17	17	17	17	17	17	17			41.0	3326008
9	2130	TW	0.29	6.8	1.5	0.25	1.5	1.4	7.0	63	61	16	16	16	16	17	18	17	17	18	17			41.3	3329716
10	1040	TW	0.27	6.8	1.5	0.25	1.5	1.3	6.9	63	61	19	15	17	16	18	16	17	16	18	17			41.9	3331027
11	1450	BM	0.31	6.8	1.5	0.28	1.7	1.6	6.9	63	61	16	15	15	16	17	16	16	16	17	17			41.4	3333839
12	0900	BM	0.27	6.8	2.0	0.28	1.6	1.4	6.9	63	61	17	16	16	16	16	16	16	16	18	17	X	X	41.3	3335669
13	0935	BM	0.32	7.0	2.0	0.26	1.7	1.4	7.1	63	61	16	15	15	15	15	15	16	15	16	16			42.1	3338132
14	1000	TW	0.33	6.8	2.0	0.26	1.6	1.4	7.0	63	61	15	15	15	15	14	15	16	16	17	17			41.9	3340602
15	1235	TW	0.32	6.7+	1.5	0.25	1.5	1.3	6.9	63	61	14	15	14	15	15	15	16	15	17	16			41.5	3343298
16	0945	BM	0.34	6.8	2.0	0.26	1.5	1.4	7.0	63	61	16	15	16	14	16	15	16	16	16	16			41.8	3345466
17	0810	BM	0.32	6.8	2.0	0.27	1.6	1.6	7.0	63	61	15	14	15	14	15	15	16	15	16	15			42.1	3347736
18	0835	BM	0.30	6.8	2.0	0.30	1.6	1.4	7.0	63	60	16	15	14	15	16	14	16	15	17	16			41.5	3350236
19	0925	BM	0.32	6.8	2.0	0.35	1.6	1.3	7.0	63	61	15	14	14	14	15	15	15	15	16	16	X		41.5	3352752
20	0830	BM	0.35	6.8	2.0	0.24	1.5	1.4	7.0	63	60	15	15	15	14	15	15	15	15	16	15			41.0	3355091
21	1045	BM	0.31	6.8	2.0	0.27	1.6	1.5	6.9	63	61	16	16	15	15	15	16	16	16	16	16			41.2	3357752
22	1035	BM	0.33	6.8	2.0	0.26	1.6	1.5	7.0	63	61	15	14	15	15	16	16	15	15	16	16			40.9	3360153
23	0925	BM	0.36	6.8	2.0	0.25	1.6	1.4	7.0	63	61	15	15	14	15	15	14	16	14	16	16			41.0	3362506
24	0825	BM	0.34	6.8	2.0	0.26	1.7	1.4	7.0	63	60	15	14	14	15	16	16	15	15	16	15			40.6	3364811
25	0900	BM	0.37	6.8	2.0	0.25	1.6	1.4	7.0	64	60	16	15	15	15	16	16	16	16	17	16			39.8	3367287
26	0835	BM	0.32	6.8	2.0	0.28	1.6	1.4	7.0	63	61	16	15	15	14	16	15	16	16	17	16	X		42.1	3369711
27	0905	BM	0.35	6.8	2.0	0.25	1.6	1.4	7.1	63	61	16	15	15	15	16	15	16	15	17	17			42.0	3372162
28	1040	TW	0.32	6.8	2.0	0.36	1.4	1.5	7.0	63	61	15	17	16	15	17	14	17	16	17	17			41.7	3374802
29	1105	TW	0.33	6.8	2.0	0.29	1.6	1.4	6.9	63	61	19	15	15	15	16	16	16	17	17	16			42.1	3377272
30	0805	BM	0.37	6.8	2.0	0.34	1.6	1.4	7.0	63	61	16	16	15	16	15	15	16	16	17	17			41.6	3379338
31																									

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.
Change Bag Filters as needed to provide adequate pressure to membranes.

MONTH Feb YEAR 2020