

DAY	TIME	CERT	Raw			Finished		Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser
		OPER	NTU	pH	temp	NTU	CLR	CLR	pH	In	Out	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	gpm	Gpd
	24 Hr	Initials			deg C	<1	mg/L	>1.2mg/L		PSI	PSI	Baseline TMP was 10 psi													
1	0855	Am	0.37	6.8	2.0	0.24	1.6	1.4	7.0	63	61	16	16	15	16	15	16	16	17	17				41.6	3379338
2	0855	Bm	0.37	6.8	2.0	0.25	1.6	1.4	7.0	63	61	15	15	15	15	15	16	15	17	16				41.7	3381811
3	0930	Bm	0.36	6.8	2.0	0.25	1.6	1.4	6.9	63	61	15	15	15	15	16	16	16	17	16	X	X		41.3	3384236
4	0735	Bm	0.33	6.8	2.0	0.25	1.4	1.4	6.9	63	61	15	15	14	15	16	16	16	15	17				41.9	3386382
5	0850	Bm	0.36	6.8	2.5	0.25	1.6	1.4	6.9	63	61	15	15	15	14	14	15	15	15	17				42.5	3388852
6	1100	TW	0.33	6.8	2.0	0.25	1.7	1.4	6.9	63	61	15	15	16	15	15	16	17	15	17				42.0	3391447
7	1435	TW	0.32	6.8	2.0	0.25	1.6	1.4	6.9	63	61	17	14	14	14	16	15	16	15	17				42.2	3394230
8	0930	Bm	0.36	6.8	2.0	0.26	1.6	1.5	7.0	63	60	15	14	15	14	16	14	15	15	16				42.1	3395976
9	11:00	Am	0.41	6.8	2.0	0.25	1.6	1.4	7.0	63	60	16	15	15	15	16	15	16	15	16				41.8	3398615
10	0830	Bm	0.41	6.8	2.5	0.25	1.6	1.4	7.0	63	60	15	15	15	14	16	15	15	16	16		X		41.2	3400663
11	0850	Bm	0.38	6.8	2.0	0.25	1.7	1.4	6.9	63	60	15	15	14	15	15	14	15	14	16				40.9	3403060
12	0900	Bm	0.37	7.0	2.5	0.25	1.6	1.5	7.1	63	60	14	15	14	14	15	14	16	16	16			41.2	40.6	3450441
13	0935	TW	0.33	6.8	2.0	0.25	1.6	1.3	6.9	63	60	15	15	15	16	17	16	14	16	17				42.0	3407895
14	12:30	Am	0.41	6.8	2.0	0.25	1.7	1.5	6.9	63	61	16	15	14	15	16	16	16	16	17				42.6	3410603
15	10:00	Am	0.44	6.8	2.0	0.25	1.4	1.3	6.9	63	61	15	16	15	15	16	16	16	16	17				42.0	3412817
16	9:15	Am	0.46	6.8	2.5	0.25	1.7	1.4	6.9	63	61	16	15	15	15	16	16	15	16	17				42.7	3415064
17	0905	Bm	0.36	6.8	2.5	0.25	1.6	1.4	6.9	63	61	16	15	15	15	16	14	17	16	17		X		42.0	3417515
18	1245	Bm	0.57	6.8	2.0	0.25	1.5	1.4	7.0	63	61	16	15	16	15	16	15	16	16	17				41.7	3420340
19	0833	Bm	0.50	6.8	2.5	0.25	1.4	1.3	6.9	63	61	15	14	15	15	16	16	16	15	17				40.5	3422112
20	1200	Bm	0.57	6.8	2.0	0.25	1.3	1.3	6.9	63	61	16	15	15	15	15	16	16	16	17				41.5	3424364
21	1:30	Am	0.55	6.8	2.0	0.25	1.4	1.4	6.9	63	61	16	15	15	14	16	15	16	16	17				41.3	3426785
22	10:30	Am	0.51	6.8	2.0	0.27	1.5	1.2	6.9	63	61	16	15	15	15	16	16	16	16	17				41.0	3428586
23	1:20	Am	0.63	6.8	2.0	0.25	1.5	1.2	6.9	63	61	16	15	15	15	16	16	16	16	17				40.3	3431008
24	0950	Bm	0.63	6.8	2.5	0.26	1.5	1.2	7.0	64	61	15	15	15	15	15	15	15	15	17		X		41.1	3432908
25	0910	Bm	0.41	6.8	2.5	0.25	1.5	1.3	7.0	68	60	15	15	15	15	15	15	15	16	16				41.3	3435351
26	11:05	Bm	0.54	6.9	2.5	0.25	1.5	1.3	6.9	64	60	15	15	15	15	15	14	15	15	16				41.0	3438051
27	10:30	Bm	0.45	6.8	2.5	0.25	1.5	1.3	7.0	62	61	15	15	14	15	16	15	16	16	16				43.1	3440386
28	2:40	Am	0.57	6.8	2.5	0.25	1.5	1.3	7.0	63	61	16	16	16	15	16	16	16	16	16				40.6	3443182
29	2:00	Am	0.55	6.8	2.5	0.23	1.4	1.2	6.9	63	61	15	15	15	15	15	15	16	15	16				42.1	3445368
30	8:20	Am	0.51	6.8	2.5	0.26	1.5	1.3	6.9	63	61	15	15	15	15	16	15	16	16	16				41.7	3447106
31	10:20	Bm	0.54	6.8	2.5	0.24	1.5	1.3	7.0	63	61	14	14	15	14	16	14	16	14	17		X		41.8	3449529

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.
Change Bag Filters as needed to provide adequate pressure to membranes.

3405441

MONTH MAR YEAR 2019 2020

[illegible]