

DAY	TIME	CERT	Raw			Finished		Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser
		OPER	NTU	pH	temp	NTU	CLR	CLR	pH	In	Out	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	gpm	Gpd
	24 Hr	Initials			deg C	<1	mg/L	>1.2mg/L		PSI	PSI	Baseline TMP was 10 psi													
1	09:30	Bm	0.52	6.8	2.5	0.24	1.4	1.3	7.0	63	61	15	15	15	14	14	15	15	14	16	16			41.7	3451619
2	09:50	Bm	0.54	6.9	2.5	0.24	1.5	1.3	6.9	63	61	14	14	14	14	14	14	16	14	16	15			41.7	3453914
3	11:45	TW	0.50	6.8	1.5	0.24	1.5	1.3	6.9	63	61	17	14	15	15	16	15	14	14	17	16			41.1	3456535
4	14:00	PK	0.61	6.8	2.0	0.24	1.5	1.2	6.9	63	61	14	14	14	14	15	14	15	15	16	15			41.2	3459123
5	16:30	PK	0.70	6.8	2.0	0.24	1.5	1.2	6.9	63	61	15	15	14	14	15	14	15	15	16	15			40.6	3461708
6	11:00	PK	0.65	6.8	2.5	0.24	1.4	1.2	6.9	63	61	15	14	14	15	16	14	15	15	16	15			40.7	3463473
7	09:15	Bm	0.72	6.8	2.5	0.24	1.4	1.2	7.0	63	61	14	15	15	14	15	15	15	15	16	15	X		40.9	3465529
8	07:50	Bm	0.82	6.8	2.5	0.24	1.5	1.3	7.0	64	60	15	15	14	15	16	15	16	16	16	16			40.2	3467600
9	08:40	Bm	0.95	6.8	2.5	0.25	1.4	1.2	7.0	63	62	15	15	15	15	16	14	15	15	16	16			41.9	3469923
10	14:10	TW	1.08	6.8	2.5	0.25	1.6	1.4	6.9	63	61	17	14	16	16	18	14	17	17	19	18			41.3	3472664
11	18:10	PK	1.31	6.8	2.5	0.25	1.5	1.2	6.9	63	61	16	16	16	16	16	16	16	16	17	17			41.8	3475282
12	13:00	PK	1.46	6.8	2.5	0.25	1.5	1.2	6.9	63	61	16	16	17	16	18	17	17	17	18	18			41.2	3477013
13	8:45	PK	1.41	6.8	2.5	0.26	1.4	1.2	6.9	63	61	16	16	16	16	17	16	17	16	18	17			41.0	3478676
14	8:45	Bm	1.26	6.8	2.0	0.26	1.5	1.3	7.0	63	61	17	17	17	17	17	17	18	18	19	18	X	X	41.1	3480701
15	8:15	Bm	1.11	6.8	2.5	0.25	1.4	1.3	6.9	63	61	17	16	16	16	17	16	17	17	18	17			41.1	3482616
16	14:40	Bm	1.03	6.9	2.5	0.25	1.4	1.3	7.0	63	61	16	15	16	15	16	16	17	16	17	17			41.2	3485203
17	15:40	PK	1.04	6.8	2.5	0.25	1.5	1.3	6.9	63	61	15	15	16	15	16	16	16	15	17	16			41.3	3487342
18	11:10	PK	1.31	6.8	2.5	0.25	1.5	1.2	6.9	63	61	16	15	16	15	16	16	16	16	17	16			40.3	3489264
19	13:05	PK	0.81	6.8	2.5	0.24	1.4	1.2	6.8	63	61	16	16	16	15	16	16	16	16	17	16			42.0	3491359
20	12:40	PK	0.86	6.7	2.5	0.24	1.4	1.3	6.8	63	61	16	16	15	15	16	16	16	16	17	16			41.5	3493407
21	9:15	Bm	0.73	6.8	2.5	0.24	1.4	1.2	6.9	63	61	15	15	15	15	16	14	15	15	16	15	X		42.3	3495126
22	8:30	Bm	0.66	6.8	3.0	0.24	1.4	1.3	6.9	63	61	15	15	14	14	15	15	15	15	16	15			42.0	3497048
23	8:00	Bm	0.79	6.8	3.0	0.25	1.5	1.3	7.0	63	61	15	15	14	14	15	15	15	15	16	16			41.7	3499015
24	10:40	TW	0.65	6.8	3.0	0.25	1.5	1.3	6.9	63	61	17	14	14	14	15	17	15	15	17	16			41.3	3501191
25	13:40	PK	0.94	6.8	3.0	0.25	1.5	1.3	6.9	63	61	16	15	15	14	15	15	15	15	17	16			40.6	3503585
26	14:00	PK	1.39	6.7	3.0	0.25	1.5	1.2	6.9	63	61	15	15	14	14	15	14	15	14	16	15			40.8	3505709
27	13:10	PK	1.43	6.7	3.5	0.25	1.4	1.2	6.9	63	61	15	15	14	14	15	14	16	15	17	15			41.1	3507529
28	09:10	Bm	2.66	6.8	3.0	0.26	1.5	1.2	6.8	64	61	16	16	15	15	15	15	15	15	17	15	X	X	40.5	3509162
29	06:50	Bm	2.25	6.8	3.0	0.27	1.7	1.2	6.9	64	61	14	14	15	14	14	14	14	15	16	15			41.1	3510951
30	07:30	Bm	2.75	6.9	3.5	0.26	1.8	1.2	7.0	52	51	9	9	10	9	9	9	9	10	10	9			22.2	3512139
31																									

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

Change Bag Filters as needed to provide adequate pressure to membranes.

DAY	TIME	CERTIFIED OPERATOR	UF		UF		UF		UF		UF		UF		UF		UF		Distribution Entry Point		Comments
			1	2	3	4	5	6	7	8	9	10	Weekly	Temp - °F -	Clear Well Level - Daily						
			MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	Gallons		
1	0700	Bm																	5600		
2	0850	Bm																	5700	RAW-6.9 DIST-6.9	
3	1145	TW																	5700		
4	14:00	AL																	5800		
5	16:30	AL																	5800		
6	11:00	AL																	5800		
7	0915	Bm	X		X		X		X		X		X		X		X		5600	RAW-6.9	
8	0750	Bm																	5800		
9	0840	Bm																	5700	RAW-6.8 DIST-7.0	
10	1410	TW																	5600		
11	18:10	AL																	5600		
12	13:00	AL																	5800		
13	8:45	AL																	5800		
14	855	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5900		
15	845	Bm																	5600		
16	815	Bm																	5300	RAW-6.9 DIST-7.0	
17	15:40	AL																	5900		
18	13:05	AL																	5900		
19	12:40	AL																	5800		
20	915	Bm	X		X		X		X		X		X		X		X		5600		
21	915	Bm																	5600		
22	830	Bm																	5600		
23	800	Bm																	5600	RAW-6.8 DIST-7.0	
24	1040	TW																	5600		
25	13:40	AL																	5800		
26	14:00	AL																	5800		
27	13:10	AL																	5600		
28	0900	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5800		
29	0650	Bm																	5600		
30	0750	Bm																	5800	RAW-6.9 DIST-7.0	
31																					