

DAY	TIME	CERT	Raw			Finished		Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser
		OPER	NTU	pH	temp	NTU	CLR	CLR	pH	In	Out	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	gpm	Gpd
	24 Hr	Initials			deg C	<1	mg/L	>1.2mg/L		PSI	PSI	Baseline TMP was 10 psi													
1	11:40	TW	2.60	6.8	3.5	.027	1.3	1.2	6.9	52	51	10	10	9	9	9	9	10	10	10	9			24.9	3513558
2	16:30	NR	3.29	6.8	4.0	.028	1.6	1.2	6.8	52	51	10	10	10	10	10	10	10	10	10	10			25.2	3515037
3	16:00	NR	3.48	6.8	4.0	.028	1.6	1.2	6.8	52	51	10	10	10	10	10	10	10	10	10	10			24.4	3516170
4	11:20	NR	3.58	6.7	4.0	.029	2.0	1.2	6.8	52	51	10	10	10	10	10	10	10	10	10	10			24.6	3517032
5	10:10	BM	3.50	6.8	4.5	.028	2.1	1.4	6.9	52	51	10	10	10	9	10	10	10	10	10	10	X		25.3	3517788
6	09:35	BM	3.25	6.8	4.5	.028	2.2	1.4	6.9	53	52	10	10	9	10	10	10	10	10	10	10			24.5	3518546
7	08:30	BM	2.99	6.9	4.5	.027	2.1	1.5	7.1	53	52	10	9	9	9	9	9	10	10	10	10			24.5	3519263
8	10:15	TW	2.77	6.8	4.5	.027	1.6	1.4	6.9	52	51	11	9	9	9	9	9	9	9	9	9			24.8	3520137
9	16:00	NR	2.72	6.8	4.5	.027	2.0	1.4	6.9	52	51	10	10	9	9	10	9	10	9	10	10			24.8	3521278
10	11:45	NR	2.68	6.8	4.5	.028	2.1	1.4	6.9	52	51	10	10	9	9	9	9	10	9	10	10			24.5	3521977
11	11:40	NR	2.35	6.8	5.0	.028	2.2	1.5	6.9	52	51	9	9	9	9	9	9	10	9	10	9			24.7	3522838
12	09:10	NR	2.21	6.8	5.0	.026	2.1	1.5	6.9	52	51	9	9	9	9	9	9	9	9	9	9	X	X	24.9	3523575
13	08:35	BM	2.13	6.9	4.5	.028	1.9	1.6	7.0	53	52	9	9	9	9	10	9	9	10	10	10			24.1	3524284
14	08:00	BM	2.31	6.9	4.5	.027	1.8	1.2	7.0	53	52	9	9	9	9	9	9	9	9	9	9			24.8	3525028
15	08:40	TW	2.38	6.8	4.5	.028	1.8	1.2	6.9	52	51	10	9	9	9	9	9	9	9	10	9			24.7	3525818
16	12:20	NR	2.29	6.8	4.5	.028	1.8	1.2	6.8	53	52	9	9	9	9	9	9	9	9	9	9			24.5	3526789
17	20:30	NR	2.48	6.8	5.0	.028	1.8	1.2	6.8	53	52	9	9	9	9	10	10	9	10	10	9			24.2	3528126
18	16:30	NR	2.27	6.8	5.0	.028	1.8	1.2	6.9	53	52	9	9	9	9	9	9	9	10	9	9			23.9	3628823
19	09:15	BM	2.46	6.8	4.5	.029	1.8	1.2	6.9	53	52	9	9	9	9	9	9	9	9	9	9	X		24.1	3529338
20	10:20	BM	3.03	6.8	4.5	.029	2.1	1.4	6.9	53	50	9	9	9	9	9	9	9	9	9	9			21.7	3530322
21	09:30	BM	1.97	6.8	4.5	.031	2.9	1.2	6.9	53	52	10	10	9	10	10	10	10	10	10	10			24.9	3531158
22	08:35	TW	1.67	6.8	4.5	.030	2.3	1.6	6.9	53	52	11	9	9	9	9	9	9	11	10	10			25.3	3531947
23	16:20	NR	1.69	6.8	5.0	.029	2.3	1.4	6.9	53	52	10	10	10	9	10	9	9	10	10	10			25.7	3533888
24	11:20	NR	1.52	6.8	4.5	.029	2.4	1.4	6.9	53	52	10	10	10	10	10	10	10	10	10	10			24.4	3534847
25	14:30	NR	1.51	6.7	5.0	.028	2.2	1.5	6.8	53	52	10	10	10	10	10	10	10	10	10	10			23.5	3538375
26	09:10	BM	0.96	6.8	5.0	.028	2.7	1.7	6.9	53	52	10	10	10	10	10	10	10	10	10	10	X	X	25.1	3537332
27	08:50	BM	1.09	6.8	5.5	.030	2.5	1.9	7.0	53	51	9	9	9	9	9	9	9	9	10	9			23.4	3538575
28	08:35	BM	1.21	6.9	5.5	.031	2.5	1.7	7.1	53	50	9	9	9	9	9	9	9	9	9	9			21.9	3539832
29	11:45	TW	0.99	6.8	5.5	.033	1.8	1.4	6.9	52	52	9	11	10	9	10	9	11	9	10	10			25.2	3541315
30	18:40	NR	1.30	6.8	6.0	.034	2.3	1.2	6.9	52	52	10	10	10	10	10	10	10	10	10	10			24.7	3543078
31	11:50	NR	1.18	6.8	5.5	.035	2.6	1.2	6.9	52	52	10	10	10	10	10	10	10	10	10	10			24.9	3544009

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

Change Bag Filters as needed to provide adequate pressure to membrnaes.

[illegible]